



2020 Annual Groundwater Monitoring Report

**Belle River Power Plant Bottom Ash
Basins
4505 King Road
China Township, Michigan**

January 2021

Prepared For:

DTE Electric Company

Prepared By:

TRC
1540 Eisenhower Place
Ann Arbor, Michigan 48108

A handwritten signature in black ink that reads "Vincent E. Buening".

Vincent E. Buening, C.P.G.
Senior Project Manager

A handwritten signature in black ink that reads "David B. McKenzie".

David B. McKenzie, P.E.
Senior Project Engineer

A handwritten signature in black ink that reads "Sarah B. Holmstrom".

Sarah B. Holmstrom, P.G.
Senior Hydrogeologist

TABLE OF CONTENTS

Executive Summary	iii
1.0 Introduction.....	1
1.1 Program Summary	1
1.2 Site Overview	1
1.3 Geology/Hydrogeology	2
2.0 Groundwater Monitoring	3
2.1 Monitoring Well Network.....	3
2.2 Semiannual Groundwater Monitoring.....	3
2.2.1 Data Summary	3
2.2.2 Data Quality Review.....	4
2.2.3 Groundwater Flow Rate and Direction.....	4
3.0 Statistical Evaluation.....	5
3.1 Establishing Background Limits	5
3.2 Data Comparison to Background Limits – First Semiannual Event (March 2020)	5
3.3 Verification Resampling for the First Semiannual Event.....	6
3.4 Data Comparison to Background Limits – Second Semiannual Event (September 2020)	6
4.0 Conclusions and Recommendations	7
5.0 Groundwater Monitoring Report Certification	8
6.0 References	9

TABLES

Table 1	Summary of Groundwater Elevation Data – March and September 2020
Table 2	Summary of Field Data – March and September 2020
Table 3	Comparison of Appendix III Parameter Results to Background Limits – March and April 2020
Table 4	Comparison of Appendix III Parameter Results to Background Limits – September 2020

FIGURES

Figure 1	Site Location Map
Figure 2	Site Plan
Figure 3	Groundwater Potentiometric Elevation Summary – March 2020
Figure 4	Groundwater Potentiometric Elevation Summary – September 2020

APPENDICES

Appendix A	Data Quality Review
------------	---------------------

Executive Summary

On April 17, 2015, the United States Environmental Protection Agency (USEPA) published the final rule for the regulation and management of Coal Combustion Residuals (CCR) under the Resource Conservation and Recovery Act (RCRA) (the CCR Rule), as amended. The CCR Rule, which became effective on October 19, 2015 (with amendments in 2018 and 2020), applies to the DTE Electric Company (DTE Electric) Belle River Power Plant (BRPP) CCR Bottom Ash Basins (BABs) CCR unit. Pursuant to the CCR Rule, no later than January 31, 2018, and annually thereafter, the owner or operator of a CCR unit must prepare an annual groundwater monitoring and corrective action report for the CCR unit documenting the status of groundwater monitoring and corrective action for the preceding year in accordance with §257.90(e). On behalf of DTE Electric, TRC Engineers Michigan, Inc., the engineering entity of TRC, has prepared this Annual Groundwater Monitoring Report for calendar year 2020 activities at the BRPP BABs CCR unit.

DTE Electric remained in detection monitoring at the BRPP BABs CCR Unit in 2020. The semiannual detection monitoring events for 2020 were completed in March and September 2020 and included sampling and analyzing groundwater within the groundwater monitoring system for the indicator parameters listed in Appendix III to the CCR Rule. As part of the statistical evaluation, the data collected during detection monitoring events are evaluated to identify statistically significant increases (SSIs) in detection monitoring parameters to determine if concentrations in detection monitoring well samples exceed prediction limits. Detection monitoring data that have been collected and evaluated in 2020 are presented in this report.

Potential SSIs over prediction limits were noted for several Appendix III constituents in one or more downgradient wells during the March 2020 and September 2020 monitoring events. These potential SSIs were either not statistically significant (i.e. verification resampling did not confirm the exceedance) or were evaluated and determined to be a result of natural variability in groundwater quality as documented in an ASD and not attributable to the BRPP BABs CCR unit. Therefore, detection monitoring will be continued at the BRPP BABs CCR unit in accordance with §257.94 of the CCR Rule. With the very thick continuous silty clay-rich confining unit beneath the BRPP BABs CCR unit, there is no reasonable probability for the uppermost aquifer to have been affected by CCR from BRPP operations that began in the 1980s.

1.0 Introduction

1.1 Program Summary

On April 17, 2015, the United States Environmental Protection Agency (USEPA) published the final rule for the regulation and management of Coal Combustion Residuals (CCR) under the Resource Conservation and Recovery Act (RCRA) (the CCR Rule), as amended. The CCR Rule, which became effective on October 19, 2015 (with amendments in 2018 and 2020), applies to the DTE Electric Company (DTE Electric) Belle River Power Plant (BRPP) CCR Bottom Ash Basins (BABs). Pursuant to the CCR Rule, no later than January 31, 2018, and annually thereafter, the owner or operator of a CCR unit must prepare an annual groundwater monitoring and corrective action report for the CCR unit documenting the status of groundwater monitoring and corrective action for the preceding year in accordance with §257.90(e). On behalf of DTE Electric, TRC Engineers Michigan, Inc., the engineering entity of TRC Environmental Corporation (TRC), has prepared this Annual Groundwater Monitoring Report for calendar year 2020 activities at the BRPP BABs CCR unit (2020 Annual Report).

This 2020 Annual Report presents the monitoring results and the statistical evaluation of the detection monitoring parameters (Appendix III to Part 257 of the CCR Rule) for the March and September 2020 semiannual groundwater monitoring events for the BRPP BABs CCR unit. Detection monitoring for these events continued to be performed in accordance with the *CCR Groundwater Monitoring and Quality Assurance Project Plan – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin (QAPP)* (TRC, July 2016; revised August 2017) and statistically evaluated per the Stats Plan (TRC, October 2017). As part of the statistical evaluation, the data collected during detection monitoring events are evaluated to identify SSIs of detection monitoring parameters compared to background levels.

1.2 Site Overview

The BRPP is located in Section 13, Township 4 North, Range 16 East, at 4505 King Road, China Township in St. Clair County, Michigan. The BRPP was constructed in the early 1980s with plant operations beginning in 1984. Prior to Detroit Edison Company's operations commencing in the 1980s, the BRPP property was generally wooded and farmland. The property has been used continuously as a coal fired power plant since Detroit Edison Company (now DTE Electric) began power plant operations at BRPP in 1984 and is generally constructed over a natural clay-rich soil base. The BABs have been in use by the BRPP since it began operation and have collected CCR bottom ash that is periodically cleaned out and either sold for beneficial reuse or disposed of at the Range Road Landfill (RRLF).

The BRPP BABs are two adjacent physical sedimentation basins that are slightly raised CCR surface impoundments referred to as the North and South BABs, located north of the BRPP. These are considered one CCR unit. The BABs receive sluiced bottom ash and other process flow water from the power plant. Discharge water from each BAB flows over an outlet weir that gravity flows to a site storm water conveyance network of ditches and pipes, then flows into the diversion basin (DB) CCR unit, which is monitored as a separate CCR unit in accordance with the CCR Rule and addressed in a separate 2020 Annual Report.

The DB is an incised CCR surface impoundment located east of the BRPP. Water flows into the DB from the North and South BABs through a network of pipes and ditches. The DB discharges to the St. Clair River with other site wastewater in accordance with a National Pollution Discharge Elimination System (NPDES) permit.

1.3 Geology/Hydrogeology

The BRPP BABs CCR unit is located approximately one-mile west of the St. Clair River. The BRPP BABs CCR unit is underlain by more than 130 feet of unconsolidated sediments, with the lower confining Bedford Shale generally encountered from 135 to 145 feet below ground surface (bgs). In general, the BRPP BABs CCR unit is initially underlain by at least 90 to as much as 136 feet of laterally extensive low hydraulic conductivity silty clay-rich deposits. The depth to the top of the confined sand-rich uppermost aquifer encountered immediately beneath the silty clay-rich deposits varies up to 46 feet within the monitoring well network and rapidly thins to the south and east of the BABs and pinches out (e.g., no longer present) to the southeast in the vicinity of SB-16-01 (Figure 1). Consequently, the uppermost aquifer is not laterally contiguous across the entire BRPP BABs CCR unit, and not present beneath the southeastern corner of the BABs.

The variability in the depth to the uppermost aquifer is a consequence of the heterogeneity of the glacial deposits and is driven by the lateral discontinuity of the sand outwash within the encapsulating fine-grained, silty clay till that confines the uppermost aquifer. There is an apparent lack of interconnection and/or significant vertical variation between the uppermost aquifer sand unit(s) encountered across the BRPP BABs CCR unit as demonstrated by the extensive amount of time (months) it took for water levels in monitoring well MW-16-02 to reach equilibrium after well construction and development (TRC, 2017).

Given the horizontally expansive clay with substantial vertical thickness that isolates the uppermost aquifer from the BRPP BABs CCR unit, the heterogeneity of the glacial deposits (with the top of the uppermost aquifer elevation across the BABs, where present varying up to 46 feet vertically), the no flow boundary where no sand or gravel is present in the southeastern portion of the BABs CCR unit area, and the apparent lack of hydraulic interconnectedness of the uppermost aquifer encountered at the BABs in some areas, it is not appropriate to infer horizontal flow direction or gradients across the BRPP BABs CCR unit.

2.0 Groundwater Monitoring

2.1 Monitoring Well Network

A groundwater monitoring system has been established for the BRPP BABs CCR unit as detailed in the *Groundwater Monitoring System Summary Report – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin Coal Combustion Residual Units* (GWMS Report) (TRC, October 2017). The detection monitoring well network for the BABs CCR unit currently consists of five monitoring wells that are screened in the uppermost aquifer.

Monitoring wells MW-16-01 through MW-16-04 and MW-16-09 are located around the north, east and south perimeter of the BABs and provide data on both background and downgradient groundwater quality that has not been affected by the CCR unit (total of five background/downgradient monitoring wells). The monitoring well locations are shown on Figure 2.

2.2 Semiannual Groundwater Monitoring

The semiannual monitoring parameters for the detection groundwater monitoring program were selected per the CCR Rule's Appendix III to Part 257 – Constituents for Detection Monitoring. The Appendix III indicator parameters consist of boron, calcium, chloride, fluoride, pH (field reading), sulfate, and total dissolved solids (TDS) and were analyzed in accordance with the sampling and analysis plan included within the QAPP. In addition to pH, the collected field parameters included dissolved oxygen, oxidation reduction potential, specific conductivity, temperature, and turbidity.

2.2.1 Data Summary

The first semiannual groundwater detection monitoring event for 2020 was performed during March 17 to 19, 2020 by TRC personnel and samples were analyzed by Eurofins TestAmerica (Eurofins) in accordance with the QAPP. Static water elevation data were collected at all five monitoring well locations. Groundwater samples were collected from the five detection monitoring wells for the Appendix III indicator parameters and field parameters. A summary of the groundwater data collected during the March 2020 event is provided on Table 1 (static groundwater elevation data), Table 2 (field data), and Table 3 (analytical results).

The second semiannual groundwater detection monitoring event for 2020 was performed during September 14 and 15, 2020 by TRC personnel and samples were analyzed by Eurofins in accordance with the QAPP. Static water elevation data were collected at all five monitoring well locations. Groundwater samples were collected from the five detection monitoring wells for the Appendix III indicator parameters and field parameters. A summary of the groundwater data collected during the September 2020 event is provided on Table 1 (static groundwater elevation data), Table 2 (field data), and Table 4 (analytical results).

2.2.2 Data Quality Review

Data from each round were evaluated for completeness, overall quality and usability, method-specified sample holding times, precision and accuracy, and potential sample contamination. The data were found to be complete and usable for the purposes of the CCR monitoring program. Data quality reviews are summarized in Appendix A.

2.2.3 Groundwater Flow Rate and Direction

As presented in the GWMS Report, and mentioned above, given the horizontally expansive clay with substantial vertical thickness that isolates the uppermost aquifer from the BRPP BABs CCR unit; the heterogeneity of the glacial deposits (with the top of the uppermost aquifer elevation across the BABs; where present, varying up to 46 feet vertically); the no flow boundary where no sand or gravel is present in the southeastern portion of the BRPP BABs CCR unit area; and the apparent lack of hydraulic interconnectedness of the uppermost aquifer encountered at the BABs in some areas, it is not appropriate to infer horizontal flow direction or gradients across the site. Groundwater elevations measured across the Site during the March 2020 sampling event are provided on Table 1 and are summarized in plan view on Figure 3. Groundwater elevations measured across the Site during the September 2020 sampling event are provided on Table 1 and are summarized in plan view on Figure 4.

Groundwater elevation data collected during the 2020 sampling events show that groundwater conditions within the uppermost aquifer are consistent with previous monitoring events and continue to demonstrate that the downgradient wells are appropriately positioned to detect the presence of Appendix III parameters that could potentially migrate from the BRPP BABs CCR unit.

3.0 Statistical Evaluation

3.1 Establishing Background Limits

As discussed in the Stats Plan, intrawell statistical methods for the BABs CCR unit were selected based on the geology and hydrogeology at the Site. (primarily the presence of clay/hydraulic barrier, the variability in the presence of the uppermost aquifer across the site, and presence of no flow boundary on the southeast side of the aquifer), in addition to other supporting lines of evidence that the aquifer is unaffected by the CCR unit (such as the consistency in concentrations of water quality data). An intrawell statistical approach requires that each downgradient well doubles as a background and compliance well, where data from each individual well during a detection monitoring event is compared to a statistical limit developed using the background dataset from that same well.

Per the Stats Plan, background limits were established for the Appendix III indicator parameters following the collection of at least eight background monitoring events using data collected from each of the five established detection monitoring wells (MW-16-01 through MW-16-04 and MW-16-09). The statistical evaluation of the background data is presented in the 2017 Annual Report. The Appendix III background limits for each monitoring well will be used throughout the detection monitoring period to determine whether groundwater has been impacted from the BRPP BABs CCR unit by comparing concentrations in the detection monitoring wells to their respective background limits for each Appendix III indicator parameter.

3.2 Data Comparison to Background Limits – First Semiannual Event (March 2020)

The concentrations of the indicator parameters in each of the detection monitoring wells (MW-16-01 through MW-16-04 and MW-16-09) were compared to their respective statistical background limits calculated from the background data collected from each individual well (i.e., monitoring data from MW-16-01 is compared to the background limit developed using the background dataset from MW-16-01, and so forth).

The comparisons of the March 2020 monitoring event data to background limits are presented on Table 3. The statistical evaluation of the March 2020 Appendix III indicator parameters showed potential initial SSIs over background for:

- Calcium at MW-16-02 and MW-16-03; and
- Boron at MW-16-09.

The sulfate exceedance at MW-16-04 during the First Semiannual Event in March 2020 has previously been demonstrated to be from natural variability and is not from a release from the CCR unit as presented in the August 2019 ASD that was included in the 2019 Annual Report.

3.3 Verification Resampling for the First Semiannual Event

Verification resampling is performed per the Stats Plan and the *USEPA's Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance* (Unified Guidance, USEPA, 2009) to achieve performance standards as specified by §257.93(g) in the CCR Rule. Per the Stats Plan, if there is an exceedance of a prediction limit for one or more of the parameters, the well(s) of concern will be resampled within 30 days of the completion of the initial statistical analysis. Only constituents that initially exceed their statistical limit (i.e., have no previously recorded SSIs) will be analyzed for verification purposes.

Verification resampling for the March 2020 event was conducted on April 30, 2020 by TRC personnel. Groundwater samples were collected for calcium at MW-16-02 and MW-16-03 and boron at MW-16-09, in accordance with the QAPP. A summary of the analytical results collected during the resampling event is provided on Table 3. The associated data quality review is included in Appendix A.

The verification results for calcium (MW-16-02 and MW-16-03) and boron (MW-16-09) are below the prediction limits, consequently the initial potential SSIs for the March 2020 detection monitoring event are not confirmed. Therefore, in accordance with the Stats Plan and the Unified Guidance, the initial exceedances are not statistically significant, and no SSIs will be recorded for the March 2020 detection monitoring event.

3.4 Data Comparison to Background Limits – Second Semiannual Event (September 2020)

The concentrations of the indicator parameters in each of the detection monitoring wells (MW-16-01 through MW-16-04 and MW-16-09) were compared to their respective statistical background limits calculated from the background data collected from each individual well (i.e., monitoring data from MW-16-01 is compared to the background limit developed using the background dataset from MW-16-01, and so forth). The comparisons of the September 2020 monitoring event are presented on Table 4. The statistical evaluation of the September 2020 Appendix III indicator parameters showed no potential initial SSIs over background.

The TDS exceedance at MW-16-01 and the sulfate exceedance at MW-16-04 during the First Semiannual Event in September 2020 have previously been demonstrated to be from natural variability and are not from a release from the CCR unit as presented in the August 2019 ASD that was included in the 2019 Annual Report.

4.0 Conclusions and Recommendations

Potential SSIs over background limits were noted for a few Appendix III constituents in one or more downgradient wells during the March and September 2020 monitoring events. These potential SSIs were either not statistically significant (i.e. verification sampling did not confirm the exceedance) or the observed concentrations were demonstrated to be a result of natural variability in groundwater quality and not attributable to the BRPP BABs CCR unit, as documented in an ASD. As discussed above and in the GWMS Report, with the presence of the vertically and horizontally extensive clay-rich confining till beneath the BRPP BABs CCR unit, there is no reasonable probability for the uppermost aquifer to have been affected by CCR from operations. Therefore, detection monitoring will be continued at the BRPP BABs CCR unit in accordance with §257.94.

No corrective actions were performed in 2020. The next semiannual monitoring event is scheduled for the second calendar quarter of 2021.


5.0 Groundwater Monitoring Report Certification

The U.S. EPA's Disposal of Coal Combustion Residuals from Electric Utilities Final Rule Title 40 CFR Part 257 §257.90(e) requires that the owner or operator of an existing CCR unit prepare an annual groundwater monitoring and corrective action report.

**Annual Groundwater Monitoring Report Certification
Belle River Power Plant Bottom Ash Basins
China Township, Michigan**

CERTIFICATION

I hereby certify that the annual groundwater and corrective action report presented within this document for the BRPP BABs CCR unit has been prepared to meet the requirements of Title 40 CFR §257.90(e) of the Federal CCR Rule. This document is accurate and has been prepared in accordance with good engineering practices, including the consideration of applicable industry standards, and with the requirements of Title 40 CFR §257.90(e).

Name: David B. McKenzie, P.E.	Expiration Date: October 31, 2021	
Company: TRC Engineers Michigan, Inc.	Date: January 29, 2021	

6.0 References

- TRC. July 2016; Revised March and August 2017. CCR Groundwater Monitoring and Quality Assurance Project Plan – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.
- TRC. October 2017. Groundwater Monitoring System Summary Report – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin Coal Combustion Residual Units, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.
- TRC. October 2017. Groundwater Statistical Evaluation Plan – DTE Electric Company Belle River Power Plant Coal Combustion Residual Bottom Ash Basins, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.
- TRC. January 2018. Annual Groundwater Monitoring Report – DTE Electric Company Belle River Power Plant Bottom Ash Basins, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.
- TRC. April 12, 2018. Alternate Source Demonstration: 2017 Initial Detection Monitoring Sampling Event Belle River Power Plant Coal Combustion Residual Bottom Ash Basins. Prepared for DTE Electric Company.
- TRC. August 8, 2019. Alternate Source Demonstration: 2019 First Semi Annual Detection Monitoring Sampling Event Belle River Power Plant Coal Combustion Residual Bottom Ash Basins. Prepared for DTE Electric Company.
- TRC. January 2020. 2019 Annual Groundwater Monitoring Report – DTE Electric Company Belle River Power Plant Bottom Ash Basins, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.
- USEPA. 2009. Statistical Analysis of Groundwater Monitoring Data at RCRA facilities, Unified Guidance. Office of Conservation and Recovery. EPA 530/R-09-007.
- USEPA. April 2015. 40 CFR Parts 257 and 261. Hazardous and Solid Waste Management System: Disposal of Coal Combustion Residuals from Electric Utilities; Final Rule. 80 Federal Register 74 (April 17, 2015), pp. 21301-21501 (80 FR 21301).
- USEPA. July 2018. 40 CFR Part 257. Hazardous and Solid Waste Management System: Disposal of Coal Combustion Residuals from Electric Utilities; Amendments to the National Minimum Criteria (Phase One, Part One); Final Rule. 83 Federal Register 146 (July 30, 2018), pp. 36435-36456 (83 FR 36435).
- USEPA. April 2018. Barnes Johnson (Office of Resource Conservation and Recovery) to James Roewer (c/o Edison Electric Institute) and Douglas Green, Margaret Fawal (Venable LLP). Re: Coal Combustion Residuals Rule Groundwater Monitoring Requirements. April 30, 2018. United States Environmental Protection Agency, Washington, D.C. 20460. Office of Solid Waste and Emergency Response, now the Office of Land and Emergency Management.

Tables

Table 1
 Summary of Groundwater Elevation Data – March and September 2020
 Belle River Power Plant Bottom Ash Basins – RCRA CCR Monitoring Program
 China Township, Michigan

Well ID	MW-16-01		MW-16-02		MW-16-03		MW-16-04		MW-16-09	
Date Installed	3/17/2016		3/15/2016		6/1/2016		3/8/2016		6/2/2016	
TOC Elevation	590.06		588.94		590.66		590.51		590.80	
Geologic Unit of Screened Interval	Sand		Sand		Silty Sand		Sand		Sand	
Screened Interval Elevation	496.3 to 491.3		494.3 to 489.3		456.0 to 451.0		468.5 to 463.5		452.3 to 447.3	
Unit	ft BTOC	ft	ft BTOC	ft	ft BTOC	ft	ft BTOC	ft	ft BTOC	ft
Measurement Date	Depth to Water	GW Elevation	Depth to Water	GW Elevation	Depth to Water	GW Elevation	Depth to Water	GW Elevation	Depth to Water	GW Elevation
03/17/2020	15.83	574.23	13.28	575.66	16.13	574.53	16.48	574.03	16.31	574.49
09/14/2020	16.16	573.90	13.58	575.36	16.46	574.20	16.83	573.68	16.60	574.20

Notes:

Elevations are reported in feet relative to the North American Vertical Datum of 1988.
 ft BTOC - feet Below top of casing.

Table 2
 Summary of Field Data – March and September 2020
 Belle River Power Plant Bottom Ash Basins – RCRA CCR Monitoring Program
 China Township, Michigan

Sample Location	Sample Date	Dissolved Oxygen (mg/L)	Oxidation Reduction Potential (mV)	pH (SU)	Specific Conductivity (umhos/cm)	Temperature (deg C)	Turbidity (NTU)
MW-16-01	3/17/2020	0.18	-103.4	7.6	1,736	10.8	2.86
	9/14/2020	0.82	-75.7	7.6	1,417	12.6	2.29
MW-16-02	3/17/2020	0.29	-78.2	7.6	1,359	10.9	3.89
	9/15/2020	1.14	-205.2	7.8	1,447	13.0	0.75
MW-16-03	3/17/2020	0.12	-114.7	7.8	1,991	11.5	1.75
	9/14/2020	0.77	-116.3	7.8	1,656	13.3	1.86
MW-16-04	3/17/2020	0.15	-130.4	7.8	1,806	13.2	94.6
	9/15/2020	1.07	-235.7	7.8	1,930	15.7	24.5
MW-16-09	3/19/2020	0.09	-182.6	8.1	3,141	11.4	207
	9/15/2020	0.80	-196.5	7.9	2,751	12.7	118

Notes:

mg/L - milligrams per liter.

mV - millivolt.

SU - standard unit.

umhos/cm - micro-mhos per centimeter.

deg C - degrees celcius.

NTU - nephelometric turbidity units.

Table 3
 Comparison of Appendix III Parameter Results to Background Limits – March and April 2020
 Belle River Power Plant BABs – RCRA CCR Monitoring Program
 China Township, Michigan

Sample Location:		MW-16-01		MW-16-02			MW-16-03			MW-16-04		MW-16-09		
Sample Date:		3/17/2020	PL	3/17/2020	4/30/2020	PL	3/17/2020	4/30/2020	PL	3/17/2020	PL	3/19/2020	4/30/2020	PL
Constituent	Unit	Data		Data			Data			Data		Data		
Appendix III														
Boron	ug/L	1,100	1,300	1,200	--	1,300	1,100	--	1,300	980	1,100	2,000	1,600	1,900
Calcium	ug/L	39,000	45,000	88,000	53,000	59,000	52,000	33,000	36,000	32,000	64,000	41,000	--	41,000
Chloride	mg/L	450	530	350	--	400	530	--	690	450	520	1,000	--	1,100
Fluoride	mg/L	1.8	1.9	1.2	--	1.3	1.8	--	1.9	1.7	1.9	1.5	--	1.8
pH, Field	SU	7.6	7.6 - 8.1	7.6	--	7.4 - 8.0	7.8	--	7.5 - 8.3	7.8	7.5 - 8.4	8.1	--	7.7 - 8.7
Sulfate	mg/L	7.2	8.1	5.2	--	20	< 1.0	--	14	36⁽¹⁾	18	9.5	--	40
Total Dissolved Solids	mg/L	930	950	770	--	890	1,100	--	1,100	1,000	1,100	1,700	--	2,000

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

-- - Not Analyzed.

SU - standard units; pH is a field parameter.

All metals were analyzed as total unless otherwise specified.

Bold font indicates an exceedance of the Prediction Limit (PL).

(1) - Concentration addressed through First 2019 Semiannual alternative source demonstration.

Table 4
 Comparison of Appendix III Parameter Results to Background Limits – September 2020
 Belle River Power Plant BABs – RCRA CCR Monitoring Program
 China Township, Michigan

Sample Location:		MW-16-01		MW-16-02		MW-16-03		MW-16-04		MW-16-09	
Sample Date:		9/14/2020	PL	9/15/2020	PL	9/14/2020	PL	9/15/2020	PL	9/15/2020	PL
Constituent	Unit	Data		Data		Data		Data		Data	
Appendix III											
Boron	ug/L	1,100	1,300	1,100	1,300	1,100	1,300	1,000	1,100	1,500	1,900
Calcium	ug/L	42,000	45,000	54,000	59,000	34,000	36,000	46,000	64,000	37,000	41,000
Chloride	mg/L	460	530	350	400	540	690	460	520	910	1,100
Fluoride	mg/L	1.8	1.9	1.2	1.3	1.7	1.9	1.7	1.9	1.4	1.8
pH, Field	SU	7.6	7.6 - 8.1	7.8	7.4 - 8.0	7.8	7.5 - 8.3	7.8	7.5 - 8.4	7.9	7.7 - 8.7
Sulfate	mg/L	7.9	8.1	4.6	20	< 1.0	14	35⁽¹⁾	18	11	40
Total Dissolved Solids	mg/L	960⁽¹⁾	950	710	890	1,000	1,100	950	1,100	1,900	2,000

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.


SU - standard units; pH is a field parameter.

All metals were analyzed as total unless otherwise specified.

Bold font indicates an exceedance of the Prediction Limit (PL).

(1) - Concentration addressed through First 2019 Semiannual alternative source demonstration.

Figures



BASE MAP FROM USGS 7.5 MINUTE TOPOGRAPHIC QUADRANGLE SERIES.




1540 Eisenhower Place
Ann Arbor, MI 48108-3284
Phone: 734.971.7080
www.trccompanies.com




PROJECT:	DTE ELECTRIC COMPANY BELLE RIVER POWER PLANT 4505 KING ROAD CHINA TOWNSHIP, MICHIGAN
TITLE:	SITE LOCATION MAP

DRAWN BY:	S. MAJOR
CHECKED BY:	J. KRENZ
APPROVED BY:	V. BUENING
DATE:	JANUARY 2021
PROJ. NO.:	370029.0003
FILE:	370029-0003-008.mxd

FIGURE 1



LEGEND

-  SOIL BORING
-  MONITORING WELL
-  DECOMMISSIONED MONITORING WELL

NOTES

1. BASE MAP IMAGERY FROM GOOGLE EARTH PRO. & PARTNERS, (3/24/2019).
2. WELL LOCATIONS SURVEYED IN MARCH, APRIL, JUNE 2016, AND JUNE 2017 BY BMJ ENGINEERS & SURVEYORS, INC.




1" = 200'
1:2,400

PROJECT:		DTE ELECTRIC COMPANY BELLE RIVER POWER PLANT BOTTOM ASH BASIN 4505 KING ROAD CHINA TOWNSHIP, MICHIGAN	
TITLE:		SITE PLAN	
DRAWN BY:	S. MAJOR	PROJ NO.:	370029.0003.0000
CHECKED BY:	J. KRENZ	FIGURE 2	
APPROVED BY:	V. BUENING		
DATE:	JANUARY 2021		



1540 Eisenhower Place
Ann Arbor, MI 48108-3284
Phone: 734.971.7080
www.trccompanies.com

Monitoring Well Screen Information			
Monitoring Well ID	Screen Interval Lithology	Screen Interval Depth (ft BGS)	Screen Interval Elevation (ft NAVD 88)
MW-16-01	Sand	92.0 - 97.0	496.3 - 491.3
MW-16-02	Sand	92.0 - 97.0	494.3 - 489.3
MW-16-03	Silty Sand to Sand	132.0 - 137.0	456.0 - 451.0
MW-16-04	Sand	119.0 - 124.0	468.5 - 463.5
MW-16-09	Sand	136.0 - 141.0	452.3 - 447.3



LEGEND

- SOIL BORING
- MONITORING WELL
- DECOMMISSIONED MONITORING WELL

MW ID
 GROUNDWATER ELEVATION (DATE)
 GROUNDWATER ELEVATION (DATE)
 etc...

FT BGS
 FEET BELOW GROUND SURFACE
FT NAVD 88
 ELEVATION RELATIVE TO THE NORTH AMERICAN VERTICAL DATUM OF 1988

NOTES

1. BASE MAP IMAGERY FROM GOOGLE EARTH PRO, (3/23/2019).
2. WELL LOCATIONS SURVEYED IN MARCH, APRIL AND JUNE 2016 AND JUNE 2017 BY BMJ ENGINEERS & SURVEYORS, INC.
3. NO SAND OR GRAVEL UNIT PRESENT ABOVE BEDROCK IN THIS LOCATION.




1" = 200'
 1:2,400

PROJECT:		DTE ELECTRIC COMPANY BELLE RIVER POWER PLANT BOTTOM ASH BASIN 4505 KING ROAD CHINA TOWNSHIP, MICHIGAN	
TITLE:		BOTTOM ASH BASINS GROUNDWATER POTENTIOMETRIC ELEVATION SUMMARY MARCH 2020	
DRAWN BY:	S. MAJOR	PROJ NO.:	370029.0003
CHECKED BY:	J. KRENZ	FIGURE 3	
APPROVED BY:	V. BUENING		
DATE:	JANUARY 2021		



1540 Eisenhower Place
 Ann Arbor, MI 48108-3284
 Phone: 734.971.7080
 www.trccompanies.com

Monitoring Well Screen Information			
Monitoring Well ID	Screen Interval Lithology	Screen Interval Depth (ft BGS)	Screen Interval Elevation (ft NAVD 88)
MW-16-01	Sand	92.0 - 97.0	496.3 - 491.3
MW-16-02	Sand	92.0 - 97.0	494.3 - 489.3
MW-16-03	Silty Sand to Sand	132.0 - 137.0	456.0 - 451.0
MW-16-04	Sand	119.0 - 124.0	468.5 - 463.5
MW-16-09	Sand	136.0 - 141.0	452.3 - 447.3



LEGEND

- SOIL BORING
- MONITORING WELL
- DECOMMISSIONED MONITORING WELL

MW ID
GROUNDWATER ELEVATION (DATE)
GROUNDWATER ELEVATION (DATE)
etc...

FT BGS
FEET BELOW GROUND SURFACE
FT NAVD 88
ELEVATION RELATIVE TO THE NORTH AMERICAN VERTICAL DATUM OF 1988

NOTES

1. BASE MAP IMAGERY FROM GOOGLE EARTH PRO, (3/23/2019).
2. WELL LOCATIONS SURVEYED IN MARCH, APRIL AND JUNE 2016 AND JUNE 2017 BY BMJ ENGINEERS & SURVEYORS, INC.
3. NO SAND OR GRAVEL UNIT PRESENT ABOVE BEDROCK IN THIS LOCATION.



1" = 200'
1:2,400

PROJECT:		DTE ELECTRIC COMPANY BELLE RIVER POWER PLANT BOTTOM ASH BASIN 4505 KING ROAD CHINA TOWNSHIP, MICHIGAN	
TITLE:		BOTTOM ASH BASINS GROUNDWATER POTENTIOMETRIC ELEVATION SUMMARY SEPTEMBER 2020	
DRAWN BY:	S. MAJOR	PROJ NO.:	370029.0003
CHECKED BY:	J. KRENZ	FIGURE 4	
APPROVED BY:	V. BUENING		
DATE:	JANUARY 2021		



1540 Eisenhower Place
Ann Arbor, MI 48108-3284
Phone: 734.971.7080
www.trccompanies.com

Appendix A

Data Quality Review

Laboratory Data Quality Review Groundwater Monitoring Event March 2020 (Detection Monitoring) DTE Electric Company Belle River Power Plant (DTE BRPP)

Groundwater samples were collected by TRC for the March 2020 sampling event for the Bottom Ash Basins and Diversion Basin at the DTE BRPP. Samples were analyzed for anions, total boron, total calcium, and total dissolved solids by Eurofins-Test America Laboratories, Inc. (Eurofins-TA), located in North Canton, Ohio. The laboratory analytical results are reported in laboratory reports 240-127905-1 and 240-128049-1.

During the March 2020 sampling event, a groundwater sample was collected from each of the following wells:

Bottom Ash Basins:

- MW-16-01
- MW-16-02
- MW-16-03
- MW-16-04
- MW-16-09

Diversion Basin:

- MW-16-05
- MW-16-06
- MW-16-07
- MW-16-08
- MW-16-10
- MW-16-11A

Each sample was analyzed for the following constituents:

Analyte Group	Method
Anions (Chloride, Fluoride, Sulfate)	SW846 9056A
Total Boron	SW846 3005A/6010B
Total Calcium	SW846 3005A/6020
Total Dissolved Solids	SM 2540C

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Data Review (USEPA, 2017). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;
- Data for method blanks and equipment blanks, where applicable. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Equipment blanks are used to assess potential contamination arising from field procedures;

- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Data for matrix spike and matrix spike duplicate samples (MS/MSDs), where applicable. The MS/MSDs are used to assess the accuracy and precision of the analytical method using a sample from the dataset;
- Data for laboratory duplicates, where applicable. The laboratory duplicates are used to assess the precision of the analytical method using a sample from the dataset;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- Appendix III constituents will be utilized for the purposes of a detection monitoring program.
- Data are usable for the purposes of the detection monitoring program.

QA/QC Sample Summary:

- There was one equipment blank submitted with this dataset (EB-01) which was associated with the low hydraulic conductivity wells (MW-16-08, MW 16-10, and MW-16-11A). Boron (32 J µg/L), calcium (44,000 µg/L), chloride (51 mg/L), fluoride (0.79 mg/L), sulfate (55 mg/L), and TDS (430 mg/L) were detected in this equipment blank. However, the sample results for boron were detected at concentrations greater than five times the blank concentration and sulfate was not detected in samples MW-16-08 and MW-16-11A; thus, there was no impact on data usability. The positive results for calcium, chloride, fluoride, and TDS in all samples, and sulfate in sample MW-16-10 were less than five times the blank concentration and are potentially biased high, as summarized in the attached table.
- Target analytes were not detected in the method blanks.
- LCS recoveries for all target analytes were within laboratory control limits.
- MS/MSD analyses were performed on sample MW-16-01 for chloride, fluoride, and sulfate, and samples MW-16-05 and MW-16-10 for fluoride and sulfate; the percent recoveries (%Rs) and relative percent differences (RPDs) were acceptable.

- MS/MSD analyses were not performed for boron and calcium in this data set. Per the project QAPP, MS/MSD analyses are required for boron and calcium at a frequency of 1 per 20 samples.
- Laboratory duplicate analyses were not performed for TDS. Per the project QAPP, laboratory duplicate analyses are required for TDS at a frequency of 1 per 20 samples.
- DUP-01 corresponds with MW-16-01; RPDs between the parent and duplicate sample were within the QC limits.
- The nondetect reporting limits (5.0 mg/L) for sulfate in samples MW-16-06, MW-16-08, and MW-16-11A were above the QAPP-specified RL (1.0 mg/L) due to a 5-fold dilution which was likely the result of elevated chloride concentrations.

**Laboratory Data Quality Review
Groundwater Monitoring Event April 2020 (Verification Sampling)
DTE Electric Company Belle River Power Plant (DTE BRPP)**

Groundwater samples were collected by TRC for the April 2020 verification sampling event at the DTE BRPP. Samples were analyzed for total and/or dissolved boron, and/or total calcium by Eurofins-Test America Laboratories, Inc. (Eurofins-TA), located in North Canton, Ohio. The laboratory analytical results are reported in laboratory report 240-129753-1.

During the April 2020 sampling event, a groundwater sample was collected from each of the following wells:

- MW-16-02
- MW-16-03
- MW-16-09

Each sample was analyzed for one or more of the following constituents:

Analyte Group	Method
Total and/or Dissolved Boron	SW846 3005A/6010B
Total Calcium	SW846 3005A/6020

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Data Review (USEPA, 2017). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;
- Data for method blanks and equipment blanks, where applicable. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Equipment blanks are used to assess potential contamination arising from field procedures;
- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Data for matrix spike and matrix spike duplicate samples (MS/MSDs), where applicable. The MS/MSDs are used to assess the accuracy and precision of the analytical method using a sample from the dataset;
- Data for laboratory duplicates, where applicable. The laboratory duplicates are used to assess the precision of the analytical method using a sample from the dataset;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- The reviewed Appendix III constituents will be utilized for the purposes of a detection monitoring program.
- Data are usable for the purposes of the detection monitoring program.

QA/QC Sample Summary:

- Equipment blanks and field blanks were not collected.
- Target analytes were not detected in the method blanks.
- LCS recoveries for all target analytes were within laboratory control limits.
- MS/MSD analyses were not performed on a sample from this data set; per the project QAPP, MS/MSD analyses are required for boron and calcium at a frequency of 1 per 20 samples.
- Laboratory duplicate analyses were not performed on a sample from this data set.
- DUP-01 corresponds with MW-16-03 and DUP-02 and corresponds with MW-16-09; relative percent differences (RPDs) between the parent and duplicate samples were within the QC limits.

**Laboratory Data Quality Review
Groundwater Monitoring Event September 2020 (Detection
Monitoring)
DTE Electric Company Belle River Power Plant (DTE BRPP)**

Groundwater samples were collected by TRC for the September 2020 sampling event for the Bottom Ash Basins and Diversion Basin at the DTE BRPP. Samples were analyzed for anions, total recoverable metals, and total dissolved solids by Eurofins-Test America Laboratories, Inc. (Eurofins-TA), located in North Canton, Ohio. The laboratory analytical results are reported in laboratory report 240-136634-1.

During the September 2020 sampling event, a groundwater sample was collected from each of the following wells:

Bottom Ash Basins:

- MW-16-01
- MW-16-02
- MW-16-03
- MW-16-04
- MW-16-09

Diversion Basin:

- MW-16-05
- MW-16-06
- MW-16-07
- MW-16-08
- MW-16-10
- MW-16-11A

Each sample was analyzed for the following constituents:

Analyte Group	Method
Anions (Chloride, Fluoride, Sulfate)	SW846 9056A
Total Recoverable Boron	SW846 3005A/6010B
Total Recoverable Calcium	SW846 3005A/6020
Total Dissolved Solids	SM 2540C

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Data Review (USEPA, 2017). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;
- Data for method blanks and equipment blanks, where applicable. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or

analytical procedures. Equipment blanks are used to assess potential contamination arising from field procedures;

- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Data for matrix spike and matrix spike duplicate samples (MS/MSDs), where applicable. The MS/MSDs are used to assess the accuracy and precision of the analytical method using a sample from the dataset;
- Data for laboratory duplicates, where applicable. The laboratory duplicates are used to assess the precision of the analytical method using a sample from the dataset;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- Appendix III constituents will be utilized for the purposes of a detection monitoring program.
- Data are usable for the purposes of the detection monitoring program.

QA/QC Sample Summary:

- There was one equipment blank submitted with this dataset (EB-01). TDS was detected at 130 mg/L in this equipment blank. However, TDS was detected at concentrations greater than five times the blank concentration in the associated wells; thus, there was no impact on data usability.
- Target analytes were not detected in the method blanks.
- LCS recoveries for all target analytes were within laboratory control limits.
- MS/MSD analyses were performed on sample EB-01 for anions; the percent recoveries (%Rs) and relative percent differences (RPDs) were acceptable for chloride and fluoride. The MS %R for sulfate exceeded the acceptance criteria; however, no data were affected as an equipment blank sample is not representative of the groundwater matrix.
- Laboratory duplicate analyses were performed for TDS on sample MW-16-05. The RPD met the acceptance criteria.
- Dup-01 corresponds with MW-16-01; RPDs between the parent and duplicate sample were within the QC limits.

- The nondetect reporting limits (2.0 mg/L) for sulfate in samples MW-16-06, MW-16-08, and MW-16-11A were above the QAPP-specified RL (1.0 mg/L) due to a 2-fold dilution which was likely the result of elevated chloride concentrations.