



2018 Annual Groundwater Monitoring  
Report

DTE Electric Company  
Belle River Power Plant Diversion Basin

4505 King Road  
China Township, Michigan

January 2019



# 2018 Annual Groundwater Monitoring Report

**DTE Electric Company  
Belle River Power Plant Diversion Basin**

*4505 King Road  
China Township, Michigan*

January 2019

*Prepared For  
DTE Electric Company*

A handwritten signature in black ink, appearing to read "Graham Crockford".

---

Graham Crockford, C.P.G.  
Senior Project Geologist

A handwritten signature in black ink, appearing to read "David B. McKenzie".

---

David B. McKenzie, P.E.  
Senior Project Engineer

TRC | DTE Electric Company

Final

X:\WPAAM\PT2\265996\03 BRPP\CCR\DB\R265996-BRPP DB.DOCX

# Table of Contents

---

Executive Summary .....	iii
1. Introduction.....	1
1.1 Program Summary .....	1
1.2 Site Overview.....	2
1.3 Geology/Hydrogeology.....	2
2. Groundwater Monitoring.....	4
2.1 Monitoring Well Network .....	4
2.2 Semiannual Groundwater Monitoring .....	4
2.2.1 Data Summary .....	5
2.2.2 Data Quality Review.....	5
2.2.3 Groundwater Flow Rate and Direction.....	5
3. Statistical Evaluation.....	7
3.1 Establishing Background Limits .....	7
3.2 Data Comparison to Background Limits – First Semiannual Event (March 2018) .....	7
3.3 Verification Resampling for the First Semiannual Event .....	7
3.4 Data Comparison to Background Limits – Second Semiannual Event (October 2018).....	8
3.5 Verification Resampling for the Second Semiannual Event .....	8
4. Conclusions and Recommendations.....	9
5. Groundwater Monitoring Report Certification.....	10
6. References.....	11

## List of Tables

Table 1	Summary of Groundwater Elevation Data – March & October 2018
Table 2	Summary of Field Data – March & October 2018
Table 3	Comparison of Appendix III Results to Background Limits – March 2018
Table 4	Comparison of Appendix III Results to Background Limits – October 2018

## List of Figures

Figure 1	Site Location Map
Figure 2	Site Plan
Figure 3	Groundwater Potentiometric Surface Map – March 2018
Figure 4	Groundwater Potentiometric Surface Map – October 2018

## List of Appendices

Appendix A	Alternate Source Demonstration
Appendix B	Data Quality Reviews

# Executive Summary

---

On April 17, 2015, the United States Environmental Protection Agency (USEPA) published the final rule for the regulation and management of Coal Combustion Residuals (CCR) under the Resource Conservation and Recovery Act (RCRA) (the CCR Rule), as amended July 30, 2018. The CCR Rule, which became effective on October 19, 2015 (amendment effective August 29, 2018), applies to the DTE Electric Company (DTE Electric) Belle River Power Plant (BRPP) CCR Diversion Basin (DB) CCR unit. Pursuant to the CCR Rule, no later than January 31, 2018, and annually thereafter, the owner or operator of a CCR unit must prepare an annual groundwater monitoring and corrective action report for the CCR unit documenting the status of groundwater monitoring and corrective action for the preceding year in accordance with §257.90(e). On behalf of DTE Electric, TRC Engineers Michigan, Inc., the engineering entity of TRC Environmental Corporation (TRC), has prepared this Annual Groundwater Monitoring Report for calendar year 2018 activities at the BRPP DB CCR unit.

In the January 31, 2018 *Annual Groundwater Monitoring Report for the Belle River Power Plant Diversion Basin*, covering calendar year 2017 activities, DTE Electric reported that sulfate was observed within groundwater at one compliance well at a concentration above background limits. Verification resampling conducted in January 2018 did not confirm the sulfate concentration above background limits; therefore, the concentration is not statistically significant, and no statistically significant increases (SSIs) were recorded for the initial detection monitoring event. As such, DTE Electric continued detection monitoring at the BRPP DB CCR unit pursuant to §257.94 of the CCR Rule.

The semiannual detection monitoring events for 2018 were completed in March and October 2018 and included sampling and analyzing groundwater within the groundwater monitoring system for the indicator parameters listed in Appendix III to the CCR Rule. As part of the statistical evaluation, the data collected during detection monitoring events are evaluated to identify SSIs in detection monitoring parameters to determine if concentrations in detection monitoring well samples exceed background levels. Detection monitoring data that has been collected and evaluated in 2018 are presented in this report.

No SSIs were recorded for the 2018 monitoring period and detection monitoring will be continued at the BRPP DB CCR unit in accordance with §257.94. In addition, with the presence of the vertically and horizontally extensive clay-rich confining till beneath the BRPP DB CCR unit, it is not possible for the uppermost aquifer to have been affected by CCR from operations. In addition, due to limitations on CCR Rule implementation timelines, the background data sets are of relatively short duration for capturing the occurrence of natural temporal changes in the aquifer.

# Section 1

## Introduction

---

### 1.1 Program Summary

On April 17, 2015, the United States Environmental Protection Agency (USEPA) published the final rule for the regulation and management of Coal Combustion Residuals (CCR) under the Resource Conservation and Recovery Act (RCRA) (the CCR Rule), as amended July 30, 2018. The CCR Rule, which became effective on October 19, 2015 (amendment effective August 29, 2018), applies to the DTE Electric Company (DTE Electric) Belle River Power Plant (BRPP) Diversion Basin (DB). Pursuant to the CCR Rule, no later than January 31, 2018, and annually thereafter, the owner or operator of a CCR unit must prepare an annual groundwater monitoring and corrective action report for the CCR unit documenting the status of groundwater monitoring and corrective action for the preceding year in accordance with §257.90(e). On behalf of DTE Electric, TRC Engineers Michigan, Inc., the engineering entity of TRC Environmental Corporation (TRC), has prepared this Annual Groundwater Monitoring Report for calendar year 2018 activities at the BRPP DB CCR unit (2018 Annual Report).

In the January 31, 2018 *Annual Groundwater Monitoring Report for the Belle River Power Plant Diversion Basin*, covering calendar year 2017 activities (2017 Annual Report), DTE Electric reported that sulfate was observed within groundwater at one compliance well at a concentration above background limits. In response, TRC performed verification resampling and reported in an alternate source demonstration (ASD) that the concentration above the background limit was not statistically significant, no SSI was recorded and there was no evidence of a release from the CCR unit. As such, DTE Electric continued detection monitoring at the BRPP DB CCR unit pursuant to §257.94 of the CCR Rule. The verification sampling and results are summarized in the *Alternate Source Demonstration: 2017 Initial Detection Monitoring Sampling Event Belle River Power Plant Coal Combustion Residual Diversion Basin*, dated April 12, 2018, (April 2018 ASD) included in Appendix A.

The semiannual detection monitoring events for 2018 were completed in March and October 2018 and included sampling and analyzing groundwater within the groundwater monitoring system for the indicator parameters listed in Appendix III to the CCR Rule. This 2018 Annual Report presents the monitoring results and the statistical evaluation of the detection monitoring parameters (Appendix III to Part 257 of the CCR Rule) for the March and October 2018 semiannual groundwater monitoring events for the BRPP DB CCR unit. Detection monitoring continued to be performed in accordance with the *CCR Groundwater Monitoring and Quality Assurance Project Plan – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin* (QAPP) (TRC, July 2016; revised August 2017) and statistically evaluated per the

*Groundwater Statistical Evaluation Plan – Belle River Power Plant Coal Combustion Residual Diversion Basin (Stats Plan) (TRC, October 2017).* As part of the statistical evaluation, the data collected during detection monitoring events are evaluated to identify SSIs of detection monitoring parameters compared to background levels.

## 1.2 Site Overview

The BRPP is located in Section 13, Township 4 North, Range 16 East, at 4505 King Road, China Township in St. Clair County, Michigan. The BRPP was constructed in the early 1980s with plant operations beginning in 1984. Prior to Detroit Edison Company's operations commencing in the 1980s, the BRPP property was generally wooded and farmland. The property has been used continuously as a coal fired power plant since Detroit Edison Company (now DTE Electric) began power plant operations at BRPP in 1984 and is generally constructed over a natural clay-rich soil base.

The DB is an incised CCR surface impoundment located west of the BRPP near the Webster Drain. Water flows into the DB from the North and South bottom ash basins (BABs) through a network of pipes and ditches. The DB discharges to the St. Clair River with other site wastewater in accordance with a National Pollution Discharge Elimination System (NPDES) permit.

## 1.3 Geology/Hydrogeology

The BRPP DB CCR unit is located approximately one-mile west of the St. Clair River. The BRPP DB CCR unit is underlain by more than 130 feet of unconsolidated sediments, with the lower confining Bedford Shale generally encountered from 135 to 145 feet below ground surface (bgs). In general, the BRPP DB CCR unit is initially underlain by at least 130 feet of laterally extensive low hydraulic conductivity silty clay-rich deposits. The silty clay-rich till was then underlain by two to seven feet of silt between the till and the underlying shale bedrock (not an aquifer) confining unit. Groundwater was encountered within this silt at the shale bedrock interface representing a potential confined uppermost aquifer in the BRPP DB CCR unit.

A definitive groundwater flow direction to the west-northwest with a mean gradient of 0.003 foot/foot within the uppermost aquifer is evident around the BRPP CCR DB CCR unit using data collected in 2016 through 2018; however, potential groundwater flow within this silt-rich uppermost aquifer is very slow (on the order of one-half foot per year).

In addition, the elevation of CCR-affected water maintained within the BRPP DB is approximately 5 feet above the potentiometric surface elevations in the uppermost aquifer at the DB CCR unit area. This suggests that if the CCR affected surface water in the DB were able to penetrate the silty clay-rich underlying confining unit that the head on that release likely would travel radially away from the DB within the uppermost aquifer. However, with the very thick continuous silty

clay-rich confining unit beneath the BRPP it is not possible for the uppermost aquifer to have been affected by CCR from BRPP operations that began in the 1980s.

Due to the relatively small footprint of the DB, the low vertical and horizontal groundwater flow velocity and radial flow potential outward from the CCR unit, and the fact that the uppermost saturated unit being monitored is isolated by a laterally contiguous silty-clay unit which significantly impedes vertical groundwater flow thus preventing the monitored saturated zone (identified as the potential uppermost aquifer) from potentially being affected by CCR, monitoring of the BRPP DB CCR unit using intrawell statistical methods is appropriate. As such, intrawell statistical approaches are being used during detection monitoring as discussed in the Stats Plan.



# Section 2

## Groundwater Monitoring

---

### 2.1 Monitoring Well Network

A groundwater monitoring system has been established for the BRPP DB CCR unit as detailed in the *Groundwater Monitoring System Summary Report – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin Coal Combustion Residual Units* (GWMS Report) (TRC, October 2017). The detection monitoring well network for the DB CCR unit currently consists of six monitoring wells that are screened in the uppermost aquifer. The monitoring well locations are shown on Figure 2.

As discussed in the Stats Plan, intrawell statistical methods for the DB CCR unit were selected based on the geology and hydrogeology at the Site (primarily the presence of clay/hydraulic barrier, the relatively small footprint of the DB, combined with low vertical and horizontal groundwater flow velocity), in addition to other supporting lines of evidence that the aquifer is unaffected by the CCR unit (such as the consistency in concentrations of water quality data). An intrawell statistical approach requires that each of the downgradient wells doubles as a background and compliance well, where data from each individual well during a detection monitoring event is compared to a statistical limit developed using the background dataset from that same well. Monitoring wells MW-16-05 through MW-16-08, MW-16-10, and MW-16-11A are generally located around the east and west perimeter of the DB and provide data on both background and downgradient groundwater quality that has not been affected by the CCR unit (total of six background/downgradient monitoring wells).

Monitoring well MW-16-11 was found to be damaged in March 2017 and could no longer be used to obtain representative groundwater samples. A casing failure was suspected when grout was observed at the base of the well and confirmed using a downhole camera assessment that identified a crack in the casing 40 feet down. The monitoring well was properly decommissioned on May 11, 2017 and replaced on May 12, 2017, with monitoring well MW-16-11A. The replacement monitoring well is located proximal to MW-16-11 to the south and was installed utilizing procedures consistent with those described in the QAPP.

### 2.2 Semiannual Groundwater Monitoring

The semiannual monitoring parameters for the detection groundwater monitoring program were selected per the CCR Rule's Appendix III to Part 257 – Constituents for Detection Monitoring. The Appendix III indicator parameters consist of boron, calcium, chloride, fluoride, pH (field reading), sulfate, and total dissolved solids (TDS) and were analyzed in accordance with the

sampling and analysis plan included within the QAPP. In addition to pH, the collected field parameters included dissolved oxygen, oxidation reduction potential, specific conductivity, temperature, and turbidity.

### 2.2.1 Data Summary

The first semiannual groundwater detection monitoring event for 2018 was performed during March 26 through 28, 2018 by TRC personnel and samples were analyzed by TestAmerica in accordance with the QAPP. Static water elevation data were collected at all six monitoring well locations. Groundwater samples were collected from the six detection monitoring wells for the Appendix III indicator parameters and field parameters. A summary of the groundwater data collected during the March 2018 event is provided on Table 1 (static groundwater elevation data), Table 2 (field data), and Table 3 (analytical results).

The second semiannual groundwater detection monitoring event for 2018 was performed during October 1 through 4, 2018 by TRC personnel and samples were analyzed by TestAmerica in accordance with the QAPP. Static water elevation data were collected at all six monitoring well locations. Groundwater samples were collected from the six detection monitoring wells for the Appendix III indicator parameters and field parameters. A summary of the groundwater data collected during the October 2018 event is provided on Table 1 (static groundwater elevation data), Table 2 (field data), and Table 4 (analytical results).

### 2.2.2 Data Quality Review

Data from each round were evaluated for completeness, overall quality and usability, method-specified sample holding times, precision and accuracy, and potential sample contamination. The data were found to be complete and usable for the purposes of the CCR monitoring program. Data quality reviews are summarized in Appendix B.

### 2.2.3 Groundwater Flow Rate and Direction

The general flow rate and direction from both groundwater monitoring events are similar to that identified in previous monitoring rounds and continues to demonstrate that the downgradient wells are appropriately positioned to detect the presence of Appendix III parameters that could potentially migrate from the BRPP DB CCR unit. Groundwater elevation data collected during the March and October 2018 sampling events show that groundwater within the uppermost aquifer generally flows to the west-northwest across the BRPP DB, consistent with previous events. Groundwater potentiometric surface elevations measured across the BRPP DB during the March and

October 2018 sampling events are provided on Table 1 and were used to construct the groundwater potentiometric surface maps shown on Figures 3 and 4, respectively.

The average hydraulic gradient throughout the BRPP DB during both of the 2018 semiannual events is estimated at approximately 0.003 ft/ft. Resulting in an estimated average seepage velocity of approximately 0.002 ft/day or 0.6 ft/year using the average hydraulic conductivity of 0.2 ft/day (TRC, 2017) and an assumed effective porosity of 0.4.

As presented in the GWMS Report, there is a horizontally expansive clay with substantial vertical thickness that isolates the uppermost aquifer from the BRPP DB CCR unit. The general flow direction in the uppermost aquifer is similar to that identified in previous monitoring rounds and continues to demonstrate that the compliance wells are appropriately positioned to detect the presence of Appendix III parameters that could potentially migrate from the BRPP DB CCR unit.

# Section 3

## Statistical Evaluation

---

### 3.1 Establishing Background Limits

Per the Stats Plan, background limits were established for the Appendix III indicator parameters following the collection of at least eight background monitoring events using data collected from each of the six established detection monitoring wells (MW-16-05 through MW-16-08, MW-16-10, and MW-16-11/11A). The statistical evaluation of the background data is presented in the 2017 Annual Report. The Appendix III background limits for each monitoring well will be used throughout the detection monitoring period to determine whether groundwater has been impacted from the BRPP DB CCR unit by comparing concentrations in the detection monitoring wells to their respective background limits for each Appendix III indicator parameter.

### 3.2 Data Comparison to Background Limits – First Semiannual Event (March 2018)

The concentrations of the indicator parameters in each of the detection monitoring wells (MW-16-05 through MW-16-08, MW-16-10, and MW-16-11A) were compared to their respective statistical background limits calculated from the background data collected from each individual well (i.e., monitoring data from MW-16-05 is compared to the background limit developed using the background dataset from MW-16-05, and so forth).

The comparisons of the March 2018 data to background limits are presented in Table 3. Based on the statistical evaluation of the March 2018 Appendix III indicator parameters, the following resample was collected in accordance with the Stats Plan:

- Fluoride at MW-16-11A.

Verification resampling is recommended per the Stats Plan and the *USEPA's Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance* (USEPA, 2009) (Unified Guidance), to achieve performance standards as specified by §257.93(g) in the CCR rules. Per the Stats Plan, if there is an exceedance of a prediction limit for one or more of the parameters, the well(s) of concern will be resampled within 30 days of the completion of the initial statistical analysis. Constituents that have been addressed by an ASD will not be analyzed for verification purposes.

### 3.3 Verification Resampling for the First Semiannual Event

Verification resampling for the March 2018 event was conducted on May 17, 2018, by TRC personnel, in accordance with the QAPP. A summary of the groundwater data collected during

the verification resampling event is provided on Table 3. The associated data quality review is included in Appendix B.

The fluoride verification result is below the prediction limit and no SSI exists from the March 2018 event for this parameter in accordance with the Stats Plan and the Unified Guidance. As such, detection monitoring was continued in accordance with §257.94 of the CCR Rule.

### **3.4 Data Comparison to Background Limits – Second Semiannual Event (October 2018)**

The comparisons of the October 2018 data to background limits are presented in Table 4. Based on the statistical evaluation of the October 2018 Appendix III indicator parameters, a resample of the following was collected in accordance with the Stats Plan:

- Calcium at MW-16-10; and
- Sulfate at MW-16-10.

### **3.5 Verification Resampling for the Second Semiannual Event**

Verification resampling for the October 2018 event was conducted on November 16, 2018 by TRC personnel, in accordance with the QAPP. A summary of the groundwater data collected during the verification resampling event is provided on Table 4. The associated data quality review is included in Appendix B.

The calcium and sulfate verification results are below the prediction limits and no SSI exists from the October 2018 event for these parameters in accordance with the Stats Plan and the Unified Guidance.

## Section 4

# Conclusions and Recommendations

---

No SSIs were recorded for the 2018 monitoring period and detection monitoring will be continued at the BRPP DB CCR unit in accordance with §257.94. As discussed above, and in the GWMS Report, with the presence of the vertically and horizontally extensive clay-rich confining till beneath the BRPP DB CCR unit, it is not possible for the uppermost aquifer to have been affected by CCR from operations. In addition, due to limitations on CCR Rule implementation timelines, the background data sets are of relatively short duration for capturing the occurrence of natural temporal changes in the aquifer. Therefore, detection monitoring will be continued at the BRPP DB CCR unit in accordance with §257.94.

No corrective actions were performed in 2018. The next semiannual monitoring event is scheduled for the second calendar quarter of 2019.

# Section 5



## Groundwater Monitoring Report Certification

The U.S. EPA's Disposal of Coal Combustion Residuals from Electric Utilities Final Rule Title 40 CFR Part 257 §257.90(e) requires that the owner or operator of an existing CCR unit prepare an annual groundwater monitoring and corrective action report.

### Annual Groundwater Monitoring Report Certification Belle River Power Plant Diversion Basin China Township, Michigan

#### CERTIFICATION

I hereby certify that the annual groundwater and corrective action report presented within this document for the BRPP DB CCR unit has been prepared to meet the requirements of Title 40 CFR §257.90(e) of the Federal CCR Rule. This document is accurate and has been prepared in accordance with good engineering practices, including the consideration of applicable industry standards, and with the requirements of Title 40 CFR §257.90(e).

Name:  David B. McKenzie, P.E.	Expiration Date:  October 31, 2019	
Company:  TRC Engineers Michigan, Inc.	Date:  <i>January 31, 2019</i>	
		 Stamp

# Section 6

## References

---

TRC Environmental Corporation. July 2016; Revised March and August 2017. CCR Groundwater Monitoring and Quality Assurance Project Plan – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.

TRC Environmental Corporation. October 2017. Groundwater Monitoring System Summary Report – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin Coal Combustion Residual Units, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.

TRC Environmental Corporation. October 2017. Groundwater Statistical Evaluation Plan – DTE Electric Company Belle River Power Plant Coal Combustion Residual Diversion Basin, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.

TRC Environmental Corporation. January 2018. Annual Groundwater Monitoring Report – DTE Electric Company Belle River Power Plant Diversion Basin, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.

TRC Environmental Corporation. April 12, 2018. Alternate Source Demonstration: 2017 Initial Detection Monitoring Sampling Event Belle River Power Plant Coal Combustion Residual Diversion Basin. Prepared for DTE Electric Company.

USEPA. 2009. Statistical Analysis of Groundwater Monitoring Data at RCRA facilities, Unified Guidance. Office of Conservation and Recovery. EPA 530/R-09-007.

USEPA. April 2015. 40 CFR Parts 257 and 261. Hazardous and Solid Waste Management System: Disposal of Coal Combustion Residuals from Electric Utilities; Final Rule. 80 Federal Register 74 (April 17, 2015), pp. 21301-21501 (80 FR 21301).

USEPA. July 2018. 40 CFR Part 257. Hazardous and Solid Waste Management System: Disposal of Coal Combustion Residuals from Electric Utilities; Amendments to the National Minimum Criteria (Phase One, Part One); Final Rule. 83 Federal Register 146 (July 30, 2018), pp. 36435-36456 (83 FR 36435).

USEPA. April 2018. Barnes Johnson (Office of Resource Conservation and Recovery) to James Roewer (c/o Edison Electric Institute) and Douglas Green, Margaret Fawal (Venable LLP). Re: Coal Combustion Residuals Rule Groundwater Monitoring Requirements. April 30, 2018. United States Environmental Protection Agency, Washington, D.C. 20460. Office of Solid Waste and Emergency Response, now the Office of Land and Emergency Management.



# Tables

---

**Table 1**  
 Summary of Groundwater Elevation Data – March & October 2018  
 Belle River Power Plant Diversion Basin – RCRA CCR Monitoring Program  
 China Township, Michigan

Well ID	MW-16-05		MW-16-06		MW-16-07		MW-16-08		MW-16-10		MW-16-11A	
Date Installed	3/4/2016		3/11/2016		3/9/2016		3/10/2016		6/6/2016		5/12/2017	
TOC Elevation	590.82		593.21		592.58		591.88		592.26		591.66	
Geologic Unit of Screened Interval	Clayey Silt/Shale Interface		Silt/Shale Interface		Silt/Shale Interface		Silt/Shale Interface		Gravelly Silt and Silty Clay		Silt and Silty Clay	
Screened Interval Elevation	449.3 to 444.3		455.0 to 450.0		456.9 to 451.9		456.3 to 451.3		444.3 to 439.3		452.5 to 447.5	
Unit	ft BTOC	ft	ft BTOC	ft	ft BTOC	ft	ft BTOC	ft	ft BTOC	ft	ft BTOC	ft
Measurement Date	Depth to Water	GW Elevation	Depth to Water	GW Elevation	Depth to Water	GW Elevation	Depth to Water	GW Elevation	Depth to Water	GW Elevation	Depth to Water	GW Elevation
3/26/2018	17.92	572.90	18.50	574.71	17.60	574.98	16.63	575.25	18.91	573.35	16.95	574.71
10/01/2018	17.03	573.79	17.84	575.37	16.95	575.63	15.91	575.97	18.05	574.21	17.08	574.58

**Notes:**

Elevations are reported in feet relative to the North American Vertical Datum of 1988.

ft BTOC - feet Below top of casing.

**Table 2**  
 Summary of Field Data – March & October 2018  
 Belle River Power Plant Diversion Basin – RCRA CCR Monitoring Program  
 China Township, Michigan

Sample Location	Sample Date	Dissolved Oxygen (mg/L)	Oxidation Reduction Potential (mV)	pH (SU)	Specific Conductivity (umhos/cm)	Temperature (deg C)	Turbidity (NTU)
MW-16-05	3/27/2018	0.25	-155.7	8.0	4,788	9.49	33.7
	10/1/2018	0.43	-212.5	8.2	4,498	12.11	35.5
MW-16-06	3/27/2018	0.19	-196.0	8.0	5,107	10.33	6.55
	10/2/2018	0.91	-167.2	7.9	4,781	14.80	3.95
MW-16-07	3/27/2018	0.12	-267.7	8.0	5,641	10.70	65.0
	10/2/2018	0.24	-183.8	8.1	5,239	14.26	30.8
MW-16-08	3/28/2018	0.18	-145.6	7.9	5,769	10.06	42.0
	10/4/2018	0.17	-165.5	8.1	5,338	12.61	71.6
MW-16-10	3/28/2018	0.23	-101.1	8.0	5,041	9.90	99.0
	10/3/2018	0.24	-85.9	7.9	4,954	12.56	49.0
MW-16-11A	3/28/2018	0.22	-118.8	8.0	5,239	9.49	14.3
	10/4/2018	0.18	-145.3	8.1	5,005	12.75	7.57

**Notes:**

mg/L - milligrams per liter.

mV - milliVolt.

SU - standard unit.

umhos/cm - micro-mhos per centimeter.

deg C - degrees celcius.

NTU - nephelometric turbidity units.

**Table 3**  
 Comparison of Appendix III Results to Background Limits – March 2018  
 Belle River Power Plant Diversion Basin – RCRA CCR Monitoring Program  
 China Township, Michigan

Sample Location:		MW-16-05		MW-16-06		MW-16-07		MW-16-08		MW-16-10		MW-16-11A		
Sample Date:		3/27/2018	PL	3/27/2018	PL	3/27/2018	PL	3/28/2018	PL	3/28/2018	PL	3/28/2018	5/17/2018 <sup>(1)</sup>	PL
Constituent	Unit	Data		Data		Data		Data		Data		Data		
<b>Appendix III</b>														
Boron	ug/L	1,900	2,000	2,100	2,200	2,100	2,100	2,000	2,300	2,100	2,300	2,000	--	2,000
Calcium	ug/L	36,000	67,000	36,000	45,000	71,000	110,000	59,000	99,000	30,000	34,000	38,000	--	80,000
Chloride	mg/L	1,500	1,600	1,600	1,800	1,700	1,800	1,900	2,000	1,500	1,800	1,700	--	1,700
Fluoride	mg/L	1.2	1.3	1.2	1.3	1.2	1.2	1.2	1.3	1.1	1.2	1.1	1.0	1.0
pH, Field	SU	8.0	7.9 - 8.5	8.0	7.5 - 8.4	8.0	7.7 - 8.4	7.9	7.5 - 8.3	8.0	7.5 - 8.8	8.0	--	7.6 - 8.6
Sulfate	mg/L	7.9	20	3.1	20	82	98	2.7	23	79	160	1.7	--	20
Total Dissolved Solids	mg/L	2,300	2,700	2,500	3,000	2,700	3,400	2,900	3,200	2,700	3,100	2,800	--	3,000

**Notes:**

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

-- = not analyzed

All metals were analyzed as total unless otherwise specified.

**Bold** font indicates an exceedance of the Prediction Limit (PL).

**RESULT** Shading and bold font indicates a confirmed exceedance of the Prediction Limit (PL).

(1) Results shown for verification sampling performed on 5/17/18.

**Table 4**  
 Comparison of Appendix III Results to Background Limits – October 2018  
 Belle River Power Plant Diversion Basin – RCRA CCR Monitoring Program  
 China Township, Michigan

Sample Location:		MW-16-05		MW-16-06		MW-16-07		MW-16-08		MW-16-10			MW-16-11A	
Sample Date:		10/1/2018	PL	10/2/2018	PL	10/2/2018	PL	10/4/2018	PL	10/3/2018	11/16/2018 <sup>(1)</sup>	PL	10/4/2018	PL
Constituent	Unit	Data		Data		Data		Data		Data			Data	
<b>Appendix III</b>														
Boron	ug/L	1,700	2,000	1,900	2,200	2,100	2,100	1,900	2,300	2,100	--	2,300	1,800	2,000
Calcium	ug/L	36,000	67,000	35,000	45,000	50,000	110,000	57,000	99,000	<b>35,000</b>	29,000	34,000	34,000	80,000
Chloride	mg/L	1,500	1,600	1,600	1,800	1,700	1,800	1,800	2,000	1,400	--	1,800	1,700	1,700
Fluoride	mg/L	1.2	1.3	1.2	1.3	1.1	1.2	1.1	1.3	1.0	--	1.2	0.98	1.0
pH, Field	SU	8.2	7.9 - 8.5	7.9	7.5 - 8.4	8.1	7.7 - 8.4	8.1	7.5 - 8.3	7.9	--	7.5 - 8.8	8.1	7.6 - 8.6
Sulfate	mg/L	9.5	20	3.3	20	78	98	< 2.0	23	<b>170</b>	89	160	< 2.0	20
Total Dissolved Solids	mg/L	2,200	2,700	2,600	3,000	2,700	3,400	2,500	3,200	2,600	--	3,100	2,400	3,000

**Notes:**

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

-- = not analyzed

All metals were analyzed as total unless otherwise specified.


**Bold** font indicates an exceedance of the Prediction Limit (PL).

**RESULT** Shading and bold font indicates a confirmed exceedance of the Prediction Limit (PL).

(1) Results shown for verification sampling performed on 11/16/18.

# Figures

---



BASE MAP FROM USGS 7.5 MINUTE TOPOGRAPHIC QUADRANGLE SERIES.



1540 Eisenhower Place  
Ann Arbor, MI 48108-3284  
Phone: 734.971.7080

PROJECT:

**DTE ELECTRIC COMPANY  
BELLE RIVER POWER PLANT  
4505 KING ROAD  
CHINA TOWNSHIP, MICHIGAN**

TITLE:

**SITE LOCATION MAP**

DRAWN BY:

J. PAPEZ

CHECKED BY:

S HOLMSTROM

APPROVED BY:

V. BUENING

DATE:

OCTOBER 2017


PROJ. NO.:

265996.0003




FILE:

265996-SLMMB.mxd

**FIGURE 1**




**LEGEND**

-  SOIL BORING
-  MONITORING WELL
-  DECOMMISSIONED MONITORING

**NOTES**

1. BASE MAP IMAGERY FROM ST. CLAIR COUNTY INFORMATION TECHNOLOGY DEPARTMENT WEBMAP, 2015.
2. WELL LOCATIONS SURVEYED IN MARCH, APRIL, JUNE 2016, AND JUNE 2017 BY BMJ ENGINEERS & SURVEYORS, INC.




PROJECT:		<b>DTE ELECTRIC COMPANY BELLE RIVER POWER PLANT 4505 KING ROAD CHINA TOWNSHIP, MICHIGAN</b>	
TITLE:		<b>SITE PLAN</b>	
DRAWN BY:	S. MAJOR	PROJ NO.:	265996.0003
CHECKED BY:	C. SCIESZKA	<b>FIGURE 2</b>	
APPROVED BY:	V. BUENING		
DATE:	JANUARY 2019		



1540 Eisenhower Place  
Ann Arbor, MI 48108-3284  
Phone: 734.971.7080  
www.trcsolutions.com






**LEGEND**

- SOIL BORING
- MONITORING WELL
- DECOMMISSIONED MONITORING WELL
- (575.47) GROUNDWATER ELEVATION (FT NAVD 88)
- GROUNDWATER ELEVATION CONTOUR (0.5-FT INTERVAL, DASHED WHERE INFERRED)

**NOTES**

1. BASE MAP IMAGERY FROM ESRI/MICROSOFT, "WORLD IMAGERY", WEB BASEMAP SERVICE LAYER.
2. WELL LOCATIONS SURVEYED IN MARCH, APRIL, AND JUNE 2016 BY BMJ ENGINEERS AND SURVEYORS. INC.
3. NO SAND OR GRAVEL UNIT PRESENT ABOVE BEDROCK IN THIS LOCATION.
4. GROUNDWATER ELEVATIONS DISPLAYED IN FEET RELATIVE TO NORTH AMERICAN VERTICAL DATUM OF 1988.
5. NU = NOT USED, ANOMALOUS GROUNDWATER ELEVATION.




1" = 200'  
1:2,400

Monitoring Well Screen Information			
Monitoring Well ID	Screen Interval Lithology	Screen Interval Depth (ft BGS)	Screen Interval Elevation (ft NAVD 88)
MW-16-05	Clayey Silt to Shale bedrock	139.0 - 144.0	449.3 - 444.3
MW-16-06	Silt to Shale bedrock	135.0 - 140.0	455.0 - 450.0
MW-16-07	Silt to Shale bedrock	133.0 - 138.0	456.9 - 451.9
MW-16-08	Silt to Shale bedrock	133.0 - 138.0	456.3 - 451.3
MW-16-10	Gravelly Silt to Silty Clay	145.0 - 150.0	444.3 - 439.3
MW-16-11	Clay and Sandy Clay	137.0 - 142.0	452.0 - 447.0
MW-16-11A	Silt to Shale bedrock	137.0 - 142.0	452.5 - 447.5

PROJECT:	<b>DTE ELECTRIC COMPANY BELLE RIVER POWER PLANT 4505 KING ROAD CHINA TOWNSHIP, MICHIGAN</b>		
TITLE:	<b>DIVERSION BASIN GROUNDWATER POTENTIOMETRIC SURFACE MAP MARCH 26, 2018</b>		
DRAWN BY:	S.MAJOR	PROJ NO.:	265996.0003
CHECKED BY:	C. SCIESZKA	<b>FIGURE 3</b>	
APPROVED BY:	V. BUENING		
DATE:	JANUARY 2019		



1540 Eisenhower Place  
Ann Arbor, MI 48108-3284  
Phone: 734.971.7080  
www.trcsolutions.com





**LEGEND**

- SOIL BORING
- MONITORING WELL
- DECOMMISSIONED MONITORING WELL
- (575.47) GROUNDWATER ELEVATION (FT NAVD 88)
- GROUNDWATER ELEVATION CONTOUR (0.5-FT INTERVAL, DASHED WHERE INFERRED)

**NOTES**

1. BASE MAP IMAGERY FROM ESRI/MICROSOFT, "WORLD IMAGERY", WEB BASEMAP SERVICE LAYER.
2. WELL LOCATIONS SURVEYED IN MARCH, APRIL, AND JUNE 2016 BY BMJ ENGINEERS AND SURVEYORS. INC.
3. NO SAND OR GRAVEL UNIT PRESENT ABOVE BEDROCK IN THIS LOCATION.
4. GROUNDWATER ELEVATIONS DISPLAYED IN FEET RELATIVE TO NORTH AMERICAN VERTICAL DATUM OF 1988.
5. NU = NOT USED, ANOMALOUS GROUNDWATER ELEVATION.



1" = 200'  
1:2,400

Monitoring Well Screen Information			
Monitoring Well ID	Screen Interval Lithology	Screen Interval Depth (ft BGS)	Screen Interval Elevation (ft NAVD 88)
MW-16-05	Clayey Silt to Shale bedrock	139.0 - 144.0	449.3 - 444.3
MW-16-06	Silt to Shale bedrock	135.0 - 140.0	455.0 - 450.0
MW-16-07	Silt to Shale bedrock	133.0 - 138.0	456.9 - 451.9
MW-16-08	Silt to Shale bedrock	133.0 - 138.0	456.3 - 451.3
MW-16-10	Gravelly Silt to Silty Clay	145.0 - 150.0	444.3 - 439.3
MW-16-11	Clay and Sandy Clay	137.0 - 142.0	452.0 - 447.0
MW-16-11A	Silt to Shale bedrock	137.0 - 142.0	452.5 - 447.5

PROJECT:	<b>DTE ELECTRIC COMPANY BELLE RIVER POWER PLANT 4505 KING ROAD CHINA TOWNSHIP, MICHIGAN</b>		
TITLE:	<b>DIVERSION BASIN GROUNDWATER POTENTIOMETRIC SURFACE MAP OCTOBER 01, 2018</b>		
DRAWN BY:	S.MAJOR	PROJ NO.:	265996.0003
CHECKED BY:	C. SCIESZKA	<b>FIGURE 4</b>	
APPROVED BY:	V. BUENING		
DATE:	JANUARY 2019		

	1540 Eisenhower Place Ann Arbor, MI 48108-3284 Phone: 734.971.7080 www.trcsolutions.com
	FILE NO.: 265996-0003-027.mxd

# Appendix A

## Alternate Source Demonstration

---

## Technical Memorandum

**Date:** April 12, 2018

**To:** Robert J. Lee  
DTE Electric Company

**From:** Graham Crockford, TRC  
David McKenzie, TRC

**Project No.:** 265996.0003.0000 Phase 003, Task 001

**Subject:** Alternate Source Demonstration: 2017 Initial Detection Monitoring Sampling Event  
Belle River Power Plant Coal Combustion Residual Diversion Basin

---

---

### Introduction

On April 17, 2015, the United States Environmental Protection Agency (USEPA) published the final rule for the regulation and management of Coal Combustion Residuals (CCR) under the Resource Conservation and Recovery Act (RCRA) (the CCR Rule). The CCR Rule, which became effective on October 19, 2015, applies to the DTE Electric Company (DTE Electric) Belle River Power Plant (BRPP) Diversion Basin (DB) CCR unit.

TRC Engineers Michigan, Inc. (TRC) prepared the 2017 Annual Groundwater Monitoring Report (Annual Report) for the BRPP DB CCR unit on behalf of DTE Electric in accordance with the requirements of §257.90(e) (TRC, 2018). The Annual Report included the results of the October 2017 semiannual groundwater monitoring event for the BRPP DB CCR unit and the statistical evaluation of the detection monitoring parameters (Appendix III to Part 257 of the CCR Rule) for the BRPP DB CCR unit. This event was the initial detection monitoring event performed to comply with §257.94. As part of the statistical evaluation, the data collected during detection monitoring events are evaluated to identify statistically significant increases (SSIs) in detection monitoring parameters to determine if concentrations in detection monitoring well samples exceed background levels. The statistical analysis was performed pursuant to §257.93(f) and (g), and in accordance with the Groundwater Statistical Evaluation Plan (Stats Plan) (TRC, 2017).

The statistical evaluation of the October 2017 Appendix III indicator parameters showed a potential SSI over background for:

- Sulfate at MW-16-07

All other Appendix III constituents were within the statistical background limits.

## Technical Memorandum

In accordance with §257.94(3)(2), DTE Electric may demonstrate that a source other than the CCR unit caused the SSI or that the SSI resulted from error in sampling, analysis, statistical evaluation, or natural variation in groundwater quality. This Alternate Source Demonstration (ASD) has been prepared to address the potential SSIs identified in the October 2017 detection monitoring event.

### Background

The BRPP is located in China Township in St. Clair County, Michigan. The BRPP was constructed in the early 1980s with plant operations beginning in 1984. The property has been used continuously as a coal fired power plant since Detroit Edison Company (now DTE Electric) began power plant operations at BRPP in 1984 and is generally constructed over a natural clay-rich soil base.

The DB is an incised CCR surface impoundment located west of the BRPP near the Webster Drain. Water flows into the DB from the North and South bottom ash basins (BABs) through a network of pipes and ditches. The DB discharges to the St. Clair River with other site wastewater in accordance with a National Pollution Discharge Elimination System (NPDES) permit.

The BRPP DB CCR unit is located approximately one-mile west of the St. Clair River. The BRPP DB CCR unit is underlain by more than 130 feet of unconsolidated sediments, with the lower confining Bedford Shale generally encountered from 135 to 145 feet below ground surface (bgs). In general, the BRPP DB CCR unit is initially underlain by at least 130 feet of laterally extensive low hydraulic conductivity silty clay-rich deposits. The silty clay-rich till was then underlain by two to seven feet of silt between the till and the underlying shale bedrock (not an aquifer) confining unit. Groundwater was encountered within this silt at the shale bedrock interface representing a potential confined uppermost aquifer in the BRPP DB CCR unit.

The detection monitoring well network for the DB CCR unit currently consists of six monitoring wells that are screened in the uppermost aquifer. As discussed in the Stats Plan, intrawell statistical methods for the DB CCR unit were selected based on the geology and hydrogeology at the Site (primarily the presence of clay/hydraulic barrier, the relatively small footprint of the DB, combined with low vertical and horizontal groundwater flow velocity), in addition to other supporting lines of evidence that the aquifer is unaffected by the CCR unit (such as the consistency in concentrations of water quality data).

### Alternate Source Demonstration

Verification resampling was performed as recommended per the Stats Plan and the USEPA's Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance (Unified Guidance, USEPA, 2009) to achieve performance standards as specified by §257.93(g) in the CCR rules. Per the Stats Plan, if there is an exceedance of a prediction limit for one or more of the parameters, the well(s) of concern will be resampled within 30 days of the completion of the initial statistical analysis. Only constituents that initially exceed their statistical limit (i.e., have no previously recorded SSIs) will be analyzed for verification purposes. As such, verification

## Technical Memorandum

resampling was conducted on January 9, 2018, by TRC personnel. A groundwater samples was collected for sulfate at monitoring well MW-16-07 in accordance with the Quality Assurance Project Plan (TRC, July 2016, revised in March and August 2017). A summary of the groundwater data collected during the verification resampling event is provided on Table 1. The associated data quality review is included in Attachment A. The sulfate verification result is within the prediction limits; consequently, the initial SSI from the October 2017 event is not confirmed. Therefore, in accordance with the Stats Plan and the Unified Guidance, the initial exceedance is not statistically significant and no SSI will be recorded for the October 2017 monitoring event.

### Conclusions and Recommendations


Based on the results of the verification resampling, the initial exceedance for sulfate at monitoring well MW-16-07 is not statistically significant; therefore, no SSI is recorded for the initial detection monitoring event. In addition, as discussed in the Annual Report, with the presence of the vertically and horizontally extensive clay-rich confining till beneath the BRPP DB CCR unit, it is not possible for the uppermost aquifer to have been affected by CCR from operations. Due to limitations on CCR Rule implementation timelines, the background data sets are of relatively short duration for capturing the occurrence of natural temporal changes in the aquifer.

Since no confirmed SSIs over background limits were identified for any of the Appendix III parameters during the October 2017 monitoring event, DTE Electric will continue with the detection monitoring program at BRPP DB CCR unit. The next semiannual monitoring event is scheduled for the second calendar quarter of 2018.

## Technical Memorandum

### Certification Statement

I hereby certify that the alternative source demonstration presented within this document for the BRPP DB CCR unit has been prepared to meet the requirements of Title 40 CFR §257.94(e) 2 of the Federal CCR Rule. This document is accurate and has been prepared in accordance with good engineering practices, including the consideration of applicable industry standards, and with the requirements of Title 40 CFR §257.94(e) 2.

Name: David B. McKenzie, P.E.	Expiration Date: October 31, 2019	 Stamp
Company: TRC Engineers Michigan, Inc.	Date: April 12, 2018	

### References

- TRC Environmental Corporation. July 2016; Revised March and August 2017. CCR Groundwater Monitoring and Quality Assurance Project Plan – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.
- TRC Environmental Corporation. October 2017. Groundwater Monitoring System Summary Report – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin Coal Combustion Residual Units, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.
- TRC Environmental Corporation. October 2017. Groundwater Statistical Evaluation Plan – DTE Electric Company Belle River Power Plant Coal Combustion Residual Diversion Basin, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.
- TRC Environmental Corporation. January 2018. Annual Groundwater Monitoring Report – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin, 4505 King Road, China Township, Michigan. Prepared for DTE Electric Company.
- USEPA. 2009. Statistical Analysis of Groundwater Monitoring Data at RCRA facilities, Unified Guidance. Office of Conservation and Recovery. EPA 530/R-09-007.

### Attachments

- Table 1. Comparison of Verification Sampling Results to Background Limits  
Attachment A. Data Quality Review

# Technical Memorandum

## Table 1



**Table 1**  
 Comparison of Verification Sampling Results to Background Limits  
 Belle River Power Plant Diversion Basin – RCRA CCR Monitoring Program  
 China Township, Michigan

Sample Location:		<b>MW-16-07</b>	
Sample Date:		1/9/2018	
Constituent	Unit	Data	PL
<b>Appendix III</b>			
Sulfate	mg/L	77	98

**Notes:**

mg/L - milligrams per liter

**RESULT** Shading and bold font indicates a confirmed exceedance of the Prediction Limit (PL).

# **Technical Memorandum**

## **Attachment A Data Quality Review**

# **Laboratory Data Quality Review**

## **Groundwater Monitoring Event January 2018 (Verification Resampling)**

### **DTE Electric Company Belle River Power Plant (DTE BRPP)**

On January 9, 2018, TRC Environmental Corporation (TRC) collected groundwater samples at MW-16-07 to verify initial sulfate results that were above the prediction limits during the October 2017 detection monitoring event. Prior to sample collection, groundwater was purged and stabilized using the low flow sampling methods followed during the October 2017 monitoring event in accordance with the *CCR Groundwater Monitoring and Quality Assurance Project Plan – DTE Electric Company Belle River Power Plant Bottom Ash Basins and Diversion Basin (QAPP)* (TRC, July 2016; revised August 2017). A groundwater sample for monitoring well MW-16-07 was analyzed for sulfate using method 9056A by Test America Laboratories, Inc. (Test America), located in Canton, Ohio. The laboratory analytical results are reported in laboratory report J90325-1.

TRC reviewed the field and laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

### **Data Quality Review Procedure**

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Data Review (USEPA, 2017). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Data for method blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures;
- Percent recoveries for matrix spike (MS) and matrix spike duplicates (MSD). Percent recoveries are calculated for each analyte spiked and used to assess bias due to sample matrix effects;
- Reporting limits (RLs) compared to project-required RLs;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes;
- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Data for laboratory duplicates. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method; and
- Overall usability of the data based on these items.

## **Review Summary**

The data quality objectives and completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

### **QA/QC Sample Summary:**

- Target analytes were not detected in the method blank.
- LCS recoveries were within laboratory control limits.
- Dup-01 corresponds with MW-16-07; relative percent differences (RPDs) between the parent and duplicate sample were within the QC limits.
- Data are usable for purposes of verification resampling.

# Appendix B

## Data Quality Reviews

---

# Laboratory Data Quality Review

## Groundwater Monitoring Event March 2018 (Detection Monitoring)

### DTE Electric Company Belle River Power Plant (DTE BRPP)

Groundwater samples were collected by TRC for the April 2018 sampling event for the Bottom Ash Basins and Diversion Basin at the DTE BRPP. Samples were analyzed for anions, total metals, and total dissolved solids by Test America Laboratories, Inc. (Test America), located in Canton, Ohio. The laboratory analytical results are reported in laboratory report J93478-1.

During the April 2018 sampling event, a groundwater sample was collected from each of the following wells:

**Bottom Ash Basins:**

- MW-16-01
- MW-16-02
- MW-16-03
- MW-16-04
- MW-16-09

**Diversion Basin:**

- MW-16-05
- MW-16-06
- MW-16-07
- MW-16-08
- MW-16-10
- MW-16-11A

Each sample was analyzed for the following constituents:

Analyte Group	Method
Anions (Chloride, Fluoride, Sulfate)	EPA 9056A
Total Metals	EPA 6010B
Total Dissolved Solids	SM 2540C

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

### Data Quality Review Procedure

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Data Review (USEPA, 2017). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Data for method blanks and equipment blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Equipment blanks are used to assess potential contamination arising from field procedures;

- Percent recoveries for matrix spike (MS) and matrix spike duplicates (MSD). Percent recoveries are calculated for each analyte spiked and used to assess bias due to sample matrix effects;
- Reporting limits (RLs) compared to project-required RLs;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes;
- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Data for laboratory duplicates. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

## **Review Summary**

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- Appendix III constituents will be utilized for the purposes of a detection monitoring program.
- Data are usable for the purposes of the detection monitoring program.

### **QA/QC Sample Summary:**

- Target analytes were not detected in the method blank.
- LCS recoveries were within laboratory control limits.
- Dup-01 corresponds with MW-16-06; relative percent differences (RPDs) between the parent and duplicate sample were within the QC limits.
- Laboratory duplicates were performed on sample Dup-01 for total dissolved solids; RPDs between the parent and duplicate sample were within the QC limits.
- MS/MSD analyses were performed on sample MW-16-04, MW-16-07, and EB\_20180327 for anions (fluoride and sulfate). Percent recoveries and RPDs were within laboratory control limits.

# Laboratory Data Quality Review

## Groundwater Monitoring Event May 2018 (Verification Resampling)

### DTE Electric Company Belle River Power Plant (DTE BRPP)

Groundwater samples were collected by TRC for the May 2018 verification resampling event for the Diversion Basin at the DTE BRPP. Samples were analyzed for fluoride by Test America Laboratories, Inc. (Test America), located in Canton, Ohio. The laboratory analytical results are reported in laboratory report J95881-1.

During the May 2018 sampling event, a groundwater sample was collected from each of the following wells:

Diversion Basin:

- MW-16-11A

Each sample was analyzed for the following constituents:

Analyte Group	Method
Anions (Fluoride)	EPA SW846 9056A

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

### Data Quality Review Procedure

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Data Review (USEPA, 2017). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Data for method blanks and equipment blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Equipment blanks are used to assess potential contamination arising from field procedures;
- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Reporting limits (RLs) compared to project-required RLs;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.



This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

## **Review Summary**

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- Appendix III constituents will be utilized for the purposes of a detection monitoring program.
- Data are usable for the purposes of the detection monitoring program.

### **QA/QC Sample Summary:**

- Target analytes were not detected in the method blank or equipment blank EB-01.
- LCS recoveries were within laboratory control limits.
- The field duplicate pair was Dup-01 with MW-16-11A; relative percent differences (RPDs) between the parent and duplicate sample were within the QC limits.

P

## Laboratory Data Quality Review

### Groundwater Monitoring Event October 2018 (Detection Monitoring) DTE Electric Company Belle River Power Plant (DTE BRPP)

Groundwater samples were collected by TRC for the October 2018 sampling event for the Bottom Ash Basins and Diversion Basin at the DTE BRPP. Samples were analyzed for anions, total metals, and total dissolved solids by Test America Laboratories, Inc. (Test America), located in North Canton, Ohio. The laboratory analytical results are reported in laboratory reports 240-102395-1 and 240-102609-1-1.

During the October 2018 sampling event, a groundwater sample was collected from each of the following wells:

**Bottom Ash Basins:**

- MW-16-01
- MW-16-02
- MW-16-03
- MW-16-04
- MW-16-09

**Diversion Basin:**

- MW-16-05
- MW-16-06
- MW-16-07
- MW-16-08
- MW-16-10
- MW-16-11A

Each sample was analyzed for the following constituents:

Analyte Group	Method
Anions (Chloride, Fluoride, Sulfate)	SW846 9056A
Total Boron	SW846 3005A/6010B
Total Calcium	SW846 3005A/6020
Total Dissolved Solids	SM 2540C

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Data Review (USEPA, 2017). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;

- Data for method blanks and equipment blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Equipment blanks are used to assess potential contamination arising from field procedures;
- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Data for matrix spike and matrix spike duplicate samples (MS/MSDs). The MS/MSDs are used to assess the accuracy and precision of the analytical method using a sample from the dataset;
- Data for laboratory duplicates. The laboratory duplicates are used to assess the precision of the analytical method using a sample from the dataset;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

### **Review Summary**

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- Appendix III constituents will be utilized for the purposes of a detection monitoring program.
- Data are usable for the purposes of the detection monitoring program.

### **QA/QC Sample Summary:**

- There was one equipment blank submitted with this dataset (EB-01\_20181003). Chloride at 1.2 mg/L and TDS at 11 mg/L were detected in this equipment blank. However, the sample results for these analytes were detected at concentrations greater than five times the blank concentrations; thus, there was no impact on data usability.
- Target analytes were not detected in the method blanks.
- LCS recoveries for all target analytes were within laboratory control limits.
- MS/MSD analyses were performed on sample MW-16-02 for the anions; the percent recoveries (%Rs) and relative percent differences (RPDs) were acceptable.

- Dup-01 corresponds with MW-16-03; RPDs between the parent and duplicate sample were within the QC limits.
- The reporting limit (2.0 mg/L) for the nondetect sulfate results in samples MW-16-08 and MW-16-11A was above the QAPP-specified RL (1.0 mg/L) due to a 2-fold dilution as a result of a difficult matrix.

**Laboratory Data Quality Review**  
**Groundwater Monitoring Event November 2018 (Verification Resampling)**  
**DTE Electric Company Belle River Power Plant (DTE BRPP)**

Groundwater samples were collected by TRC for the November 2018 sampling event for the Diversion Basin at the DTE BRPP. Samples were analyzed for sulfate and calcium by Test America Laboratories, Inc. (TestAmerica), located in North Canton, Ohio. The laboratory analytical results are reported in laboratory report 240-104669-1.

During the November 2018 sampling event, a groundwater sample was collected from the following well:

Diversion Basin:

- MW-16-10

The sample was analyzed for the following constituents:

Analyte Group	Method
Sulfate	SW-846 9056A
Calcium	SW-846 3005A/6020

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

### **Data Quality Review Procedure**

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Data Review (USEPA, 2017). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Data for method blanks and equipment blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Equipment blanks are used to assess potential contamination arising from field procedures;
- Percent recoveries for matrix spike (MS) and matrix spike duplicates (MSD), when available. Percent recoveries are calculated for each analyte spiked and used to assess bias due to sample matrix effects;
- Reporting limits (RLs) compared to project-required RLs;

- Data for blind field duplicates, when available. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes;
- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Data for laboratory duplicates, when available. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

## **Review Summary**

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- The reviewed constituents will be utilized for the purposes of a detection monitoring program.
- Data are usable for the purposes of the detection monitoring program.

### **QA/QC Sample Summary:**

- Target analytes were not detected in the method blanks.
- One equipment blank (EB-01) was collected on 11/15/18, the day before the samples were collected after purging the well and after decontamination of the pump. Sulfate and calcium were not detected in the equipment blank, but a 5-fold dilution was performed for calcium. Since the concentration of calcium in the associated samples MW-16-10 and DUP-01 were greater than 5x the RL for calcium in the sample EB-01, there was no adverse impact on data usability.
- LCS recoveries were within laboratory control limits.
- MS/MSD analyses were performed on sample EB-01 for sulfate. Since the MS/MSD analyses were performed on an equipment blank, the MS/MSD results are not applicable and thus, were not evaluated.
- The field duplicate pair samples were DUP-01 and MW-16-10. The relative percent differences (RPDs) between the parent and duplicate sample were within the acceptance limit for sulfate and calcium.

- Laboratory duplicate analyses were not performed with this data set for sulfate and calcium even though the project QAPP indicates that laboratory duplicate analyses should be performed at a frequency of 1 in 20 samples when MS/MSD analyses are not performed (Note that the MS/MSD on sample EB-01 for sulfate was not applicable since this was an equipment blank sample). However, there was not impact on the data usability since a field duplicate pair was included with this data set and the precision was acceptable for both sulfate and calcium.