



NTH Consultants, Ltd.

Infrastructure Engineering
and Environmental Services

41780 Six Mile Road, Suite 200
Northville, MI 48168
248.553.6300
248.324.5179 Fax

Mr. Christopher Scieszka
DTE Electric Company
One Energy Plaza
Detroit, Michigan 48226

October 14, 2021
NTH Project No. 62-210081-01

**RE: Inflow Design Flood Control System Plan 5-Year Periodic Assessment
St. Clair Power Plant Bottom Ash Basins
East China Township, Michigan**

Dear Mr. Scieszka:

NTH Consultants, Ltd. (NTH) has completed a periodic update to the initial inflow design flood control (IDFC) system plan for the bottom ash basins at St. Clair Power Plant (STCPP) in accordance with the Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals (CCR) from Electric Utilities 40 CFR Part 257.82. Specifically, this IDFC system plan constitutes the 5-year periodic assessment of the initial plan (dated October 14, 2016) for these impoundments, as required by 40 CFR Part 257.82(c)(4). NTH performed this assessment using information provided by personnel from DTE Electric Company (DTE), observations we made during a site visit by our personnel, and an updated topographic survey. In general, the analysis methods and development of information are presented in the initial IDFC system plan and are not reiterated herein. This letter identifies changes to the conditions documented in the initial plan and stipulates any new information made available to NTH as part of the periodic assessment that may alter or re-affirm the findings from the initial 2016 evaluation, which is attached to the end of the report for reference.

BACKGROUND

The STCPP bottom ash basins are physical sedimentation basins and receive bottom ash and other process flow effluent pumped from the power plant. Discharge water from the basins flows over an outlet weir and gravity flows to a site storm water conveyance network, which outfalls with other site stormwater effluent to STCPP overflow canal authorized via a National Pollution Discharge Elimination System (NPDES) permit. The basins are incised CCR surface impoundments, per the definition in 40 CFR 257.53 and therefore, a 25-year storm event was used for the assessment.

NTH prepared an IDFC system plan in 2016 to document and demonstrate the hydrologic and hydraulic capacity and performance conditions of the CCR surface impoundments, including the basins, intake structures, and downstream hydraulic structures in accordance with 40 CFR 257.82. We previously determined that the existing downstream conveyance system experienced deficiencies when modeled at the 25-year storm event because the system was surcharged due to the water level of the St. Clair River, which is where the basins eventually outfall through the plant overflow canal. The outfall of the basins is routinely submerged depending on the current water surface elevation of the St. Clair River. The deficiencies were independent of the hydraulic



performance of the bottom ash basins and outfall structures themselves and does not impact the overall hydraulic performance of the basins. In addition, the discharge from the basins meets the regulatory NPDES permit requirements for total suspended solids (TSS) and fats, oils, and grease (FOG), so the impoundment discharge water submerging the conveyance structures downstream would not be considered a release of CCR or regulated wastewater and would therefore be an operational item, not a regulatory consideration.

ASSESSMENT

For this periodic evaluation, NTH performed the following to analyze the condition of the bottom ash basins and verify the information presented in the initial IDFC report:

- Performed a site visit on July 29, 2021 to meet DTE personnel, learn about any changes to the DTE assets, and observe the current system conditions. A photo log from the site visit is included as an attachment to this letter;
- Reviewed the initial report;
- Procured supplemental topographic and bathymetric surveying of the bottom ash basins. The supplemental survey was performed on May 10, 2021 by BMJ Engineers & Surveyors, Inc. to update previous bathymetric information from 2016 and to facilitate accurate capacity calculations for the system. The supplemental survey information is included as an attachment to this letter;
- Obtained flow data from the last five years of process water inletting to the basins and confirmed that there were no changes to the stormwater flows entering the system downstream of the basins;
- Updated the model input parameters including new peak flow information and updated basin capacity according to the bathymetric survey. The updated site plan is included as attachment to this letter; and
- Re-ran the Autodesk Storm and Sanitary Analysis (SSA) modeling software with the updated data inputs. The updated model output is included as an attachment to this letter.

Based on information from the above actions, NTH summarizes the following for the IDFC periodic assessment:

- The current configuration and condition of the basins (as shown in the attached photographs) are consistent with those presented in the initial IDFC report. DTE personnel indicated that no alterations have been made to the basins and no substantive changes were apparent during NTH's field observation.
- The capacity of the basins has not significantly changed from that presented in the initial IDFC report, but both increased:
 - 1.9 million gallons for the west basin (1.5 million gallons in 2016) and
 - 1.4 million gallons for the east basin (1.1 million gallons in 2016).

As a point of clarification, the capacity of the basins at any given time is a function of the active dredging state and is not necessarily indicative of changes to the basin geometry. The west basin weir controls the basin water levels and flow and NTH staff observed no indication that the basin or weir geometries have been altered since the initial IDFC report.



- Analysis of the inflow data provided by DTE showed that the average flows are lower than the flows from the initial report; however, the maximum flow that was experienced is higher than in the initial report. This higher value was used in the model and did not significantly alter the results of the initial report. It should be noted that there were a significant number of days (41% over the last 5 years) when high water levels in the St. Clair River resulted in flow meter data that could not be used due to the river water elevation being higher than the elevation of the overflow weir. The days which had flows that were affected by the high river levels were not used in the determination of the maximum and average flows. The previous and current input information is summarized in the following table.

STCPP Bottom Ash Basin Inflow Rate Summary

Flow Rates		
	Previous Report	Current
Maximum Flow (cfs)	27.14	33.16
Average Flow (cfs)	7.36	7.07

- The pattern and controls of the process flow system are consistent with that documented in the initial report. No substantive changes were apparent during NTH's field observation.
- The dimensions and capacities of the receiving stormwater system was unchanged from the initial IDFC report based on our document review and observations.
- Information from the supplemental survey indicates basin water surface elevations are consistent with that documented in the initial IDFC report.
- The initial water surface elevation in the SSA model was updated for the weir box node and CB-1 node downstream of the basins to match the ordinary high-water mark of the St. Clair River (Elevation 578.7) at the US Army Corps of Engineers St. Clair monitoring location directly upstream of STCPP. This did not change the conclusion that the downstream conveyance capacity is still deficient due to submerged conditions.

Based on the findings summarized above, the inflow design flood control system plan presented in the initial report is applicable to the current condition of the STCPP bottom ash basins. The deficiencies of the downstream conveyance system still exist, but are still believed to be an operational item, not a regulatory one, as the discharge from the basins meets the regulatory requirements of the NPDES permit and is not considered a release of CCR material.

CONCLUSIONS

Based on the findings summarized herein and the hydrologic and hydraulic capacity requirements for CCR surface impoundments presented in 40 CFR 257.82, NTH has determined that the bottom ash basins of the STCPP meet the criteria of this section. In accordance with 40 CFR



Mr. Christopher Scieszka
October 14, 2021

257.82(c)(5), a statement of Certification for the STCPP bottom ash basins is included with this letter as an attachment. A copy of this letter should be kept in the facility's operating record for future reference.

Please contact NTH if you have any questions.

Sincerely,

NTH Consultants, Ltd.

DocuSigned by:
David R. Lutz
2BF41F0D0F4749B...

David R. Lutz, P.E.
Vice President

DocuSigned by:
Samantha L. Grant
A1E1683045E447D...

Samantha L. Grant, P.E.
Project Engineer

DRL/SLG/mam

Attachments

of the sampling system. The mean of the distribution of the number of individuals sampled in a particular trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1). The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1).

When the number of individuals sampled in a trap was 1 or 2, the sex ratio was 1.00 and 1.06, respectively. When the number of individuals sampled in a trap was 3 or 4, the sex ratio was 1.01 and 1.02, respectively. When the number of individuals sampled in a trap was 5 or 6, the sex ratio was 1.00 and 1.00, respectively. When the number of individuals sampled in a trap was 7 or 8, the sex ratio was 1.00 and 1.00, respectively.

The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1). The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1).

The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1). The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1).

The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1). The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1).

The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1). The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1).

The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1). The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1).

The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1). The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1).

The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1). The mean number of individuals per trap was 2.44, and the variance was 1.26. The distribution was not significantly different from a Poisson distribution (Table 1).



Inflow Design Flood Control System Plan
Bottom Ash Basins CCR Periodic Assessment
St. Clair Power Plant
East China Township, Michigan



Photograph 1: East Basin Inlet Pipes from Northwest Corner of East Basin Looking East



Inflow Design Flood Control System Plan
Bottom Ash Basins CCR Periodic Assessment
St. Clair Power Plant
East China Township, Michigan



Photograph 2: East Basin Box Culvert Inlet from North End of Basin Looking Southwest



Inflow Design Flood Control System Plan
Bottom Ash Basins CCR Periodic Assessment
St. Clair Power Plant
East China Township, Michigan



Photograph 3: East Basin Looking South from North End



Inflow Design Flood Control System Plan
Bottom Ash Basins CCR Periodic Assessment
St. Clair Power Plant
East China Township, Michigan



Photograph 4: East Basin Box Culvert Opening from Southwest Corner of East Basin Looking Northwest



Inflow Design Flood Control System Plan
Bottom Ash Basins CCR Periodic Assessment
St. Clair Power Plant
East China Township, Michigan



Photograph 5: West Basin Box Culvert Opening from East Side of West Basin Looking South



Inflow Design Flood Control System Plan
Bottom Ash Basins CCR Periodic Assessment
St. Clair Power Plant
East China Township, Michigan



Photograph 6: West Basin Looking North from South End



Inflow Design Flood Control System Plan
Bottom Ash Basins CCR Periodic Assessment
St. Clair Power Plant
East China Township, Michigan



Photograph 7: West Basin Weir Looking East from Northwest Corner of West Basin



Inflow Design Flood Control System Plan
Bottom Ash Basins CCR Periodic Assessment
St. Clair Power Plant
East China Township, Michigan



Photograph 8: West Basin Outlet Looking East from Northwest Corner of West Basin

the 1990s, the number of people in the world who are under 15 years of age is expected to increase from 1.1 billion to 1.4 billion.

There are a number of reasons why the number of children in the world is increasing. One of the main reasons is that the number of children who are surviving to the age of 15 is increasing. This is due to a number of factors, including improved medical care, better nutrition, and a decrease in child mortality.

Another reason why the number of children in the world is increasing is that the number of children who are being born is increasing. This is due to a number of factors, including a decrease in the age at which women are having children, and an increase in the number of children who are being born to women who are already having children.

There are a number of other factors that are contributing to the increase in the number of children in the world. These include a decrease in the number of children who are being adopted, and an increase in the number of children who are being born to women who are already having children.

The increase in the number of children in the world is a cause for concern. This is because it is expected that the number of children who are living in poverty will increase, and that the number of children who are being born to women who are already having children will continue to increase.

There are a number of things that can be done to help reduce the number of children in the world. These include providing better medical care, improving nutrition, and decreasing child mortality.

It is also important to provide education and training for women, so that they can make informed decisions about when to have children and how many children to have.

Finally, it is important to provide support for women who are already having children, so that they can better care for their children and avoid having more children.

By taking these steps, we can help to reduce the number of children in the world, and improve the lives of the children who are already here.



The number of children in the world is increasing, and this is a cause for concern. However, there are a number of things that can be done to help reduce the number of children in the world, and improve the lives of the children who are already here.

By providing better medical care, improving nutrition, and decreasing child mortality, we can help to reduce the number of children who are living in poverty, and improve the lives of the children who are already here.

It is also important to provide education and training for women, so that they can make informed decisions about when to have children and how many children to have. Finally, it is important to provide support for women who are already having children, so that they can better care for their children and avoid having more children.

By taking these steps, we can help to reduce the number of children in the world, and improve the lives of the children who are already here.

ST. CLAIR POWER PLANT ASH SETTLING BASINS



NOTES:

VERTICAL DATUM: DTE PLANT DATUM (ORIGIN UNKNOWN)




HORIZONTAL DATUM: DTE PLANT DATUM (ORIGIN UNKNOWN)

BENCHMARK:

DESCRIPTION: ATOP CUT \boxtimes IN CONCRETE BASE OF LIGHT POST ON THE EASTERLY SIDE OF THE WESTERLY ASH SETTLING BASIN ON THE SOUTH END.
ELEVATION = 586.18 (PLANT DATUM)

WATER LEVEL

EAST POND ELEVATION = 579.13 (PLANT DATUM)
WEST POND ELEVATION = 579.05 (PLANT DATUM)





NO.	REVISIONS	DATE



NTH Consultants, Ltd.
Infrastructure Engineering and Environmental Services

Northville, MI	248.553.6300
Detroit, MI	313.237.3900
Lansing, MI	517.484.8900
Grand Rapids, MI	616.451.0270
Cleveland, OH	216.334.4040



SUBMITTAL			
REV	DESCRIPTION	DATE	BY
1	5-YR PERIODIC ASSESSMENT	9/7/2021	DGD

PROJECT NAME:
DTE ST. CLAIR POWER PLANT - BOTTOM ASH BASIN HYDRAULIC ANALYSIS

PROJECT LOCATION:
**ST. CLAIR POWER PLANT
EAST CHINA TOWNSHIP,
MICHIGAN**

LEGEND	
	EXISTING CONTOUR LINE
	EXISTING GRAVEL DRIVE
	EXISTING BUILDING
	EXISTING GUARDRAIL
	EXISTING PIPING
	EXISTING MANHOLE
	DRAINAGE BOUNDARY

NOTE: EXISTING TOPOGRAPHIC SURVEY COMPLETED BY MCNEELY LINCOLN AND ASSOCIATES ON APRIL 8, 11, AND MAY 27, 2016. LOCATION OF OVERFLOW CANAL FROM HISTORICAL DRAWINGS PROVIDED BY DTE. SUPPLEMENTAL SURVEY WAS PERFORMED ON MAY 10, 2021 BY BMJ ENGINEERS & SURVEYORS, INC. TO UPDATE PREVIOUS BATHYMETRIC INFORMATION.

NTH PROJECT NO.:	CAD FILE NAME:
62-210081	210081-SC-SP
DESIGNED BY:	INCEP DATE:
SLG	9/7/2016
DRAWN BY:	DRAWING SCALE:
SLG	1" = 30'
CHECKED BY:	SUBMITTED DATE:
DRL	9/7/2021
SHEET TITLE:	
ST. CLAIR POWER PLANT BOTTOM ASH BASIN	
EXISTING SYSTEM COMPONENT PLAN	
SHEET REFERENCE NUMBER:	

c:\Users\adobony\desktop\J drive local\210081\production_neth\ktopp\210081-sc-sp.dwg Plotter: P/P/2021 2:01 PM by adobony

DTE St. Clair Power Plant

Existing System Model Output

Autodesk® Storm and Sanitary Analysis 2020 - Version 13.3.206 (Build 0)

Project Description

File Name St. Clair.SPF

Analysis Options

Flow Units cfs
Subbasin Hydrograph Method. Rational
Time of Concentration..... SCS TR-55
Return Period..... 25 years
Link Routing Method Hydrodynamic
Storage Node Exfiltration.. None
Starting Date SEP-03-2021 00:00:00
Ending Date SEP-03-2021 02:00:00
Report Time Step 00:00:10

Element Count

Number of subbasins 3
Number of nodes 5
Number of links 4

Subbasin Summary

Subbasin	Total Area
ID	ft ²
Sub-01	55201.49
Sub-02	43837.17
Sub-03	21363.92

Node Summary

DTE St. Clair Power Plant

Existing System Model Output

Node ID	Element Type	Invert Elevation ft	Maximum Elev. ft	Ponded Area ft ²	External Inflow
CB-1	JUNCTION	573.00	583.78	0.00	Yes
Outfall	OUTFALL	572.50	576.50	0.00	
East-Basin	STORAGE	571.70	582.51	0.00	Yes
Weir-Box	STORAGE	570.69	583.88	0.00	
West-Basin	STORAGE	573.01	583.88	0.00	

Link Summary

Link ID	From Node	To Node	Element Type	Length ft	Slope %	Manning's Roughness
48-in-1	Weir-Box	CB-1	CONDUIT	191.3	0.0314	0.0130
48-in-2	CB-1	Outfall	CONDUIT	66.0	0.7576	0.0130
Box-Culvert	East-Basin	West-Basin	CHANNEL	66.0	0.3030	0.0130
Weir	West-Basin	Weir-Box	WEIR			

Cross Section Summary

Link ID	Shape	Depth/Diameter ft	Width ft	No. of Barrels	Cross Sectional Area ft ²	Full Flow Hydraulic Radius ft	Design Flow Capacity cfs
48-in-1	CIRCULAR	4.00	4.00	1	12.57	1.00	25.44
48-in-2	CIRCULAR	4.00	4.00	1	12.57	1.00	125.03
Box-Culvert	RECT_OPEN	6.90	8.70	1	60.03	2.67	726.63

Runoff Quantity Continuity

	Volume acre-ft	Depth inches
Total Precipitation	0.255	1.107
Continuity Error (%)	0.107	

Flow Routing Continuity

Volume acre-ft	Volume Mgallons

DTE St. Clair Power Plant

Existing System Model Output

```

*****
External Inflow ..... 6.159 2.007
External Outflow ..... 5.801 1.890
Initial Stored Volume .... 13.951 4.546
Final Stored Volume ..... 14.536 4.737
Continuity Error (%) ..... 0.000
    
```

 Runoff Coefficient Computations Report

 Subbasin Sub-01

Soil/Surface Description	Area (ft ²)	Soil Group	Runoff Coeff.
-	55201.49	-	0.90
Composite Area & Weighted Runoff Coeff.	55201.49		0.90

 Subbasin Sub-02

Soil/Surface Description	Area (ft ²)	Soil Group	Runoff Coeff.
-	43837.17	-	0.90
Composite Area & Weighted Runoff Coeff.	43837.17		0.90

 Subbasin Sub-03

Soil/Surface Description	Area (ft ²)	Soil Group	Runoff Coeff.
-	21363.92	-	0.90
Composite Area & Weighted Runoff Coeff.	21363.92		0.90

 SCS TR-55 Time of Concentration Computations Report

Sheet Flow Equation

DTE St. Clair Power Plant

Existing System Model Output

$$T_c = (0.007 * ((n * L_f)^{0.8})) / ((P^{0.5}) * (S_f^{0.4}))$$

Where:

Tc = Time of Concentration (hrs)
n = Manning's Roughness
Lf = Flow Length (ft)
P = 2 yr, 24 hr Rainfall (inches)
Sf = Slope (ft/ft)

Shallow Concentrated Flow Equation

V = 16.1345 * (Sf^{0.5}) (unpaved surface)
V = 20.3282 * (Sf^{0.5}) (paved surface)
V = 15.0 * (Sf^{0.5}) (grassed waterway surface)
V = 10.0 * (Sf^{0.5}) (nearly bare & untilled surface)
V = 9.0 * (Sf^{0.5}) (cultivated straight rows surface)
V = 7.0 * (Sf^{0.5}) (short grass pasture surface)
V = 5.0 * (Sf^{0.5}) (woodland surface)
V = 2.5 * (Sf^{0.5}) (forest w/heavy litter surface)
Tc = (Lf / V) / (3600 sec/hr)

Where:

Tc = Time of Concentration (hrs)
Lf = Flow Length (ft)
V = Velocity (ft/sec)
Sf = Slope (ft/ft)

Channel Flow Equation

V = (1.49 * (R^(2/3)) * (Sf^{0.5})) / n
R = Aq / Wp
Tc = (Lf / V) / (3600 sec/hr)

Where:

Tc = Time of Concentration (hrs)
Lf = Flow Length (ft)
R = Hydraulic Radius (ft)
Aq = Flow Area (ft²)
Wp = Wetted Perimeter (ft)
V = Velocity (ft/sec)

DTE St. Clair Power Plant

Existing System Model Output

Sf = Slope (ft/ft)
n = Manning's Roughness

Subbasin Sub-01

User-Defined TOC override (minutes): 2.80

Subbasin Sub-02

User-Defined TOC override (minutes): 4.30

Subbasin Sub-03

User-Defined TOC override (minutes): 12.00

Subbasin Runoff Summary

Subbasin ID	Accumulated Precip in	Rainfall Intensity in/hr	Total Runoff in	Peak Runoff cfs	Weighted Runoff Coeff	Time of Concentration days	hh:mm:ss
Sub-01	1.11	4.43	1.00	5.05	0.900	0	00:15:00
Sub-02	1.11	4.43	1.00	4.01	0.900	0	00:15:00
Sub-03	1.11	4.43	1.00	1.96	0.900	0	00:15:00

Node Depth Summary

Node ID	Average Depth Attained ft	Maximum Depth Attained ft	Maximum HGL Attained ft	Time of Max Occurrence days	hh:mm	Total Flooded Volume acre-in	Total Time Flooded minutes	Retention Time hh:mm:ss

DTE St. Clair Power Plant

Existing System Model Output

CB-1	5.87	6.64	579.64	0	00:00	0	0	0:00:00
Outfall	6.20	6.20	578.70	0	00:00	0	0	0:00:00
East-Basin	7.56	7.59	579.29	0	00:28	0	0	0:00:00
Weir-Box	8.37	8.43	579.12	0	00:27	0	0	0:00:00
West-Basin	6.23	6.26	579.27	0	00:28	0	0	0:00:00

Node Flow Summary

Node ID	Element Type	Maximum Lateral Inflow cfs	Peak Inflow cfs	Time of Peak Inflow Occurrence days hh:mm	Maximum Flooding Overflow cfs	Time of Peak Flooding Occurrence days hh:mm
CB-1	JUNCTION	6.05	38.58	0 00:26	0.00	
Outfall	OUTFALL	0.00	38.58	0 00:26	0.00	
East-Basin	STORAGE	38.21	38.21	0 00:15	0.00	
Weir-Box	STORAGE	0.00	34.19	0 00:29	0.00	
West-Basin	STORAGE	4.01	35.91	0 00:18	0.00	

Storage Node Summary

Storage Node ID	Maximum Poned Volume 1000 ft ³	Maximum Poned Volume (%)	Time of Max Poned Volume days hh:mm	Average Poned Volume 1000 ft ³	Average Poned Volume (%)	Maximum Storage Node Outflow cfs	Maximum Exfiltration Rate cfm	Time of Max. Exfiltration Rate hh:mm:ss	Total Exfiltrated Volume 1000 ft ³
East-Basin	342.881	73	0 00:28	341.610	73	33.75	0.00	0:00:00	0.000
Weir-Box	11.320	62	0 00:27	11.240	62	34.23	0.00	0:00:00	0.000
West-Basin	274.952	56	0 00:28	273.666	56	34.19	0.00	0:00:00	0.000

Outfall Loading Summary

Outfall Node ID	Flow Frequency	Average Flow	Peak Inflow
-----------------	----------------	--------------	-------------

DTE St. Clair Power Plant

Existing System Model Output

	(%)	cfs	cfs
----- Outfall	100.00	35.09	38.58
----- System	100.00	35.09	38.58

Link Flow Summary

Link ID	Element Type	Time of Peak Flow Occurrence days hh:mm	Maximum Velocity Attained ft/sec	Length Factor	Peak Flow during Analysis cfs	Design Flow Capacity cfs	Ratio of Maximum /Design Flow	Ratio of Maximum Flow Depth	Total Time Surcharged minutes	Reported Condition
48-in-1	CONDUIT	0 00:30	2.72	1.00	34.23	25.44	1.35	1.00	120	SURCHARGED
48-in-2	CONDUIT	0 00:26	3.07	1.00	38.58	125.03	0.31	1.00	120	SURCHARGED
Box-Culvert	CHANNEL	0 00:27	1.12	1.00	33.75	726.63	0.05	0.50	0	Calculated
Weir	WEIR	0 00:29			34.19			0.06		

Highest Flow Instability Indexes

All links are stable.

Analysis began on: Tue Sep 7 17:14:57 2021
Analysis ended on: Tue Sep 7 17:14:57 2021
Total elapsed time: < 1 sec

the 1990s, the number of people who have been employed in the public sector has increased in all countries.

There are a number of reasons for the increase in public sector employment. One of the main reasons is the increasing demand for public services. As the population ages, there is a need for more social security, health care, and education. In addition, the demand for public services has increased in many other areas, such as transportation, housing, and environmental protection.

Another reason for the increase in public sector employment is the increasing size of the public sector. In many countries, the public sector has grown significantly in size over the past few decades. This has led to a corresponding increase in the number of public sector employees.

There are also a number of other factors that have contributed to the increase in public sector employment. For example, the increasing number of people who are entering the workforce has led to a corresponding increase in the number of public sector employees. In addition, the increasing number of people who are leaving the workforce has led to a corresponding increase in the number of public sector employees.

Overall, the increase in public sector employment is a result of a number of factors. The increasing demand for public services, the increasing size of the public sector, and the increasing number of people entering and leaving the workforce are all factors that have contributed to the increase in public sector employment.

The increase in public sector employment has had a number of effects on the economy. One of the main effects is the increase in government spending. As the number of public sector employees increases, the government must spend more money on salaries and benefits. This has led to a corresponding increase in government spending.

Another effect of the increase in public sector employment is the increase in government revenue. As the number of public sector employees increases, the government must collect more money in taxes. This has led to a corresponding increase in government revenue.

Overall, the increase in public sector employment has had a number of effects on the economy. The increase in government spending and the increase in government revenue are both effects of the increase in public sector employment.

The increase in public sector employment has also had a number of effects on the labor market. One of the main effects is the increase in the number of people who are employed in the public sector. This has led to a corresponding increase in the number of people who are employed in the economy.

Another effect of the increase in public sector employment is the increase in the number of people who are unemployed. As the number of public sector employees increases, the number of people who are unemployed also increases. This is because the public sector is a large employer, and its expansion has led to a corresponding increase in the number of people who are unemployed.

Overall, the increase in public sector employment has had a number of effects on the labor market. The increase in the number of people who are employed in the public sector and the increase in the number of people who are unemployed are both effects of the increase in public sector employment.

The increase in public sector employment has also had a number of effects on the social sector. One of the main effects is the increase in the number of people who are employed in the social sector. This has led to a corresponding increase in the number of people who are employed in the economy.

Another effect of the increase in public sector employment is the increase in the number of people who are unemployed. As the number of public sector employees increases, the number of people who are unemployed also increases. This is because the public sector is a large employer, and its expansion has led to a corresponding increase in the number of people who are unemployed.



STATEMENT OF CERTIFICATION

I, David R. Lutz, a Professional Engineer licensed in the State of Michigan, certify¹ that NTH Consultants, Ltd. have reviewed available historical information, conducted a field visit, performed engineering and hydraulic/hydrologic analysis, modeling, and calculations on the inflow design flood control system for the bottom ash CCR surface impoundments at the DTE St. Clair Power Plant, located in East China Township, Michigan. To the best of my knowledge and belief, the analysis and documentation presented in this report for the bottom ash basins at the aforementioned facility is accurate and has been developed in substantial conformance with the requirements stipulated in 40 CFR Part 257.82.



David R. Lutz, P.E.
State of Michigan Professional Engineer
Registration No. 57487

(1) I am rendering my professional opinion based on the information available to me at the time of this report's writing. This certification does not comprise a guarantee or warranty that certain conditions exist, nor does it relieve any other party of their requirements to abide by all applicable local, state, and federal regulations, and to honor all express or customary guarantees and warranties associated with their work.

the 1990s, the number of people with diabetes has increased in all industrialized countries.

Diabetes is a chronic disease with a high prevalence. In the Netherlands, the prevalence of diabetes is 6.5% (1.5% of the population with type 1 diabetes and 5% with type 2 diabetes) [1]. The prevalence of diabetes is expected to increase in the next 20 years, especially in the developing countries.

Diabetes is a complex disease with a multifactorial aetiology. The aetiology of type 1 diabetes is still unclear, but it is thought to be an autoimmune disease. The aetiology of type 2 diabetes is thought to be a combination of genetic and environmental factors. The most important environmental factors are obesity and sedentary lifestyle.

Diabetes is a chronic disease with a high prevalence. In the Netherlands, the prevalence of diabetes is 6.5% (1.5% of the population with type 1 diabetes and 5% with type 2 diabetes) [1]. The prevalence of diabetes is expected to increase in the next 20 years, especially in the developing countries.

Diabetes is a complex disease with a multifactorial aetiology. The aetiology of type 1 diabetes is still unclear, but it is thought to be an autoimmune disease. The aetiology of type 2 diabetes is thought to be a combination of genetic and environmental factors. The most important environmental factors are obesity and sedentary lifestyle.

Diabetes is a chronic disease with a high prevalence. In the Netherlands, the prevalence of diabetes is 6.5% (1.5% of the population with type 1 diabetes and 5% with type 2 diabetes) [1]. The prevalence of diabetes is expected to increase in the next 20 years, especially in the developing countries.

Diabetes is a complex disease with a multifactorial aetiology. The aetiology of type 1 diabetes is still unclear, but it is thought to be an autoimmune disease. The aetiology of type 2 diabetes is thought to be a combination of genetic and environmental factors. The most important environmental factors are obesity and sedentary lifestyle.

Diabetes is a chronic disease with a high prevalence. In the Netherlands, the prevalence of diabetes is 6.5% (1.5% of the population with type 1 diabetes and 5% with type 2 diabetes) [1]. The prevalence of diabetes is expected to increase in the next 20 years, especially in the developing countries.

Diabetes is a complex disease with a multifactorial aetiology. The aetiology of type 1 diabetes is still unclear, but it is thought to be an autoimmune disease. The aetiology of type 2 diabetes is thought to be a combination of genetic and environmental factors. The most important environmental factors are obesity and sedentary lifestyle.

Diabetes is a chronic disease with a high prevalence. In the Netherlands, the prevalence of diabetes is 6.5% (1.5% of the population with type 1 diabetes and 5% with type 2 diabetes) [1]. The prevalence of diabetes is expected to increase in the next 20 years, especially in the developing countries.

Diabetes is a complex disease with a multifactorial aetiology. The aetiology of type 1 diabetes is still unclear, but it is thought to be an autoimmune disease. The aetiology of type 2 diabetes is thought to be a combination of genetic and environmental factors. The most important environmental factors are obesity and sedentary lifestyle.

Report

Inflow Design Flood Control System Plan St. Clair Power Plant St. Clair, Michigan

**DTE Energy Company
One Energy Plaza, Detroit, MI**

**October 14, 2016
NTH Project No. 62-160047-04**

NTH Consultants, Ltd.
41780 Six Mile Road
Northville, MI 48168





TABLE OF CONTENTS

	<u>Page No.</u>
INTRODUCTION	1
Regulatory Basis	1
MODELING OF CCR IMPOUNDMENT SYSTEM	2
Model Input	2
Model Input Assumptions	5
Existing System Components	5
Model Output	6
Analysis of Design Flood Event – Existing Conditions	7
CONCLUSIONS	9
STATEMENT OF CERTIFICATION	10
ATTACHMENTS	
REFERENCE DOCUMENTS	



INTRODUCTION

NTH Consultants, Ltd. (NTH), in conjunction with personnel from DTE Energy Company (DTE), has completed an inflow design flood control system plan for the bottom ash basins at St. Clair Power Plant (STCPP) in accordance with the Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals (CCR) from Electric Utilities 40 CFR Part 257.82. This plan details the hydraulic and hydrologic capacity of the CCR impoundment system, including the basins, intake structures, and downstream hydraulic structures. The intent of the plan is to ensure that the CCR impoundment has the capacity to manage the discharge from the process flows along with a specified design rainfall event “inflow design flood”, based on the hazard potential classification of the basins.

The STCPP was constructed in the 1950’s in St. Clair, Michigan and is located just east of the DTE Belle River Power Plant (BRPP). The power plant is located on the peninsula formed by the St. Clair and Belle Rivers, approximately 3 miles south of St. Clair. The bottom ash basins are physical sedimentation basins, located south of SCTPP next to the St. Clair River and receive bottom ash and other process flow effluent pumped from the power plant. Discharge water from the basins flows over an overflow weir and gravity flows to a site storm water conveyance network, which eventually outfalls with other site storm water effluent authorized via a National Pollution Discharge Elimination System (NPDES) permit into the Overflow Canal. An overall site plan is included as Figure 1, in the attachments.

Regulatory Basis

In accordance with 40 CFR Part 257.82, NTH has prepared this inflow design flood control system plan to demonstrate and document the hydrologic and hydraulic capacity and performance requirements for the bottom ash CCR surface impoundments. Specifically, this plan details how the bottom ash CCR surface impoundments collect and control the peak discharge from the inflow design flood, in addition to the peak discharge into the impoundments from plant process flow. The inflow design flood requirements for the capacity evaluation depend on the hazard potential classification of the basins in accordance



with 40 CFR 257.82(a)(3). The basins at STCPP are not required to be classified in accordance with 40 CFR 257.73(a)(2), because the basins are incised CCR impoundments based on the definition prescribed in 40 CFR 257.53. Because of this, the STCPP bottom ash CCR surface impoundments system are being analyzed to handle a 25-year flood event in addition to the plant process flows. As stipulated in Section VI (H)(3) of the rule preamble, the plan also includes a:

- Characterization of the design storm, catchment area, run-on and run-off routing models;
- Characterization of the intake, decant, and spillway structures and their capacity;
- Characterization of the downstream hydraulic structures which receive the discharge from the CCR surface impoundments; and
- Supporting engineering calculations and analysis results.

MODELING OF CCR IMPOUNDMENT SYSTEM

NTH evaluated the bottom ash CCR surface impoundment system using the Autodesk[®] Storm and Sanitary Analysis 2017 computer modeling software. This software was used to develop runoff hydrographs for the watersheds contributing to the system as well as to route the inflow hydrographs through the bottom ash CCR impoundment and conveyance structures.

Model Input

In order to compile the data necessary for input into the model, NTH conducted several steps including:

- Performed a site visit to meet DTE personnel, learn about the DTE assets, and field review the existing system conditions;
- Reviewed historic site drawings and flow data provided by DTE plant staff; and



- Procured ground surface topographical elevations by McNeely & Lincoln Associates (MLA), a registered land surveyor, on April 8, 11, and May 27, 2016. MLA also sounded the bottom of the basins to allow for accurate capacity calculations and surveyed components of the system, including the basins, the weir and box structure, and pipe and manhole inverts (see NTH Figure 2 for the detailed survey information).

NTH performed the analysis using design precipitation data adopted from the National Oceanic Atmospheric Administration (NOAA) Atlas 14, Volume 8, Version 2 (2013). We evaluated the bottom ash CCR surface impoundment system for a 25-year storm event and utilized the rational method to calculate the storm water runoff generated from each of the sub-watersheds. The rational method determines the peak discharge rate from each sub-watershed based on the following equation:

$$Q = CiA$$

Where:

Q = Peak discharge rate (cubic feet per second (CFS))

C = Runoff coefficient (presented in table below)

i = Rainfall intensity from IDF curves based on design storm return period and Tc (in/hr)

A = Sub-watershed drainage area (Acres)

The CCR bottom ash basin system was divided into sub-watersheds based on existing ground topography to determine the contributing runoff amount for each basin. The downstream conveyance structure, which ultimately receives the discharge from the impoundments, also receives stormwater from various locations on the STCPP site. The contributing area, time of concentration, and runoff coefficient were determined for each watershed area. These input parameters are used to determine both the amount and intensity of runoff generated in each watershed during the design storm and the overall amount of runoff collected and conveyed by the storm water system (see Figure 3 for depiction of drainage areas).



The time of concentration, T_c , is the time required for the entire sub-watershed to contribute runoff to the system and is dependent on flow path, slope and ground type. In general, T_c for each sub-area was very small due to the small nature of the watersheds. Based on state-of-the-practice engineering standards, we utilized a minimum T_c of 15 minutes for each sub-watershed, which is the minimum amount of time used in a typical analysis, even though the actual flow time may be much less. The model was allowed to run for a 2-hour duration to allow enough time for all of the storm water runoff from the design storm to contribute to the CCR impoundment and the downstream structures.

The runoff coefficient is a function of land use and ground condition. We adopted runoff coefficients from our past experience and generally-acceptable industry standards. The runoff coefficients used for this study are summarized in the following table:

Ground Type	Runoff Coefficient (C)
Grass	0.30
Pavements/Parking Lots	0.90
Compacted Gravel Covered Areas	0.85

We selected the hydrodynamic routing method in Storm and Sanitary Analysis software program because it is the most sophisticated method and produces the most theoretically accurate results. It solves the one-dimensional Saint-Venant flow equations which consist of continuity and momentum equations for pipes and ditches and a volume continuity equation at the storage nodes and junctions. This routing method can represent pressurized flows when the piping becomes full and can model the amount of flooding in storage nodes and junctions.

See attached Figure 3 which depicts the CCR system and contributing drainage areas based on the results of our field survey and investigation, and review of historical site drawings. Refer to the attached model output results for additional input information.



Model Input Assumptions

NTH utilized information obtained from topographic surveys, historical information, and field investigations to build the model of the CCR impoundment and conveyance network. When available, items such as pipe/manhole diameter, inverts, material of construction, and inlet/cover type were utilized to accurately model the conveyance network.

Additionally, NTH obtained three years of historical flow data from DTE plant staff to characterize the process flows into the bottom ash CCR surface impoundment system. This included daily flow readings from an electronic integrator to measure process flows. NTH completed a statistical analysis to determine appropriate parameters for the peak flows to use for the:

- East Bottom Ash Basin through (2) 8-inch diameter inlet pipes; and
- East Bottom Ash Basin through 4'-5" wide x 4'-0" deep inlet box culvert.

While every attempt was made to accurately model the existing system, assumptions introduce unknown parameters into the model. If any of these assumptions are incorrect, the results of the model will be impacted. Should actual conditions vary from the assumptions utilized in the model, the predicted model results, and subsequent recommendations to correct any deficiencies identified, may be impacted. We have relatively high confidence that the model for the CCR impoundment and conveyance structures depicts the most conservative anticipated conditions during the modeled flood events.

Existing System Components

There are two bottom ash basins at STCPP, the east basin and the west basin, hydraulically connected by an 8'-7" wide x 11'-0" deep, 65-foot long box culvert. Per a review of historical construction drawings, the bottom ash basins, which have the same general dimensions in a "U" shape, were reconstructed in-place with tied-back steel sheet pile walls in 1995. The east basin has a capacity of 1.1 million gallons and the west basin has a capacity of 1.5 million gallons.



Sluiced bottom ash enters the east basin on the north side through two 8-inch pipes at grade and a 4'-5" wide x 4'-0" deep box culvert. The box culvert intercepts five pipes from various parts of the plant. DTE staff-provided flow data for the basins for the past three years indicated the peak flow out of the west basin was 27.1 cubic feet per second (cfs).

The west basin discharges over an overflow weir into an outfall structure on the north side of the basin. The weir spans the entire width of the basin (approximately 84 feet) and the outfall structure flows into a 48-inch reinforced concrete pipe (RCP) which ultimately outfalls to the STCPP underground overflow canal. The 48-inch RCP flows to a catch basin north of the basins and combines with another 48-inch pipe bringing stormwater flow from various places on-site from the west. NTH used historical drawings to determine the possible contributing areas bringing additional stormwater to the other 48-inch pipe at the catch basin. We collaborated with DTE staff to determine which areas were still contributing to the pipe and which had been abandoned or re-routed to other stormwater collection systems. NTH calculated the stormwater to have a peak flow of 4.1 cfs, based on contributory drainage areas confirmed by DTE staff during field investigation. The combined flow (stormwater and bottom ash basin discharge water) then continues north and outfalls into the overflow canal.

The water levels in the bottom ash basins are controlled by the fixed elevation of the outlet weir on the west basin, establishing a normal water level in the basins at 579.0 feet. High water level in the basins was determined to be 579.4 in the topographic survey by observed water staining on the sheet pile walls. The top of sheet pile for the east basin is 582.5 and the top of sheet pile for the west basin is 583.9.

Model Output

The model produces output from the basin watersheds that includes inflow, outflow, peak outflow rate, and total runoff inflow/outflow volumes. The model also provides output from the CCR impoundment and conveyance structures including peak flow rates / velocities,



maximum hydraulic grade lines, flow depths, and flooding/surcharged structures. To determine where system deficiencies exist, the results were analyzed for:

1. Locations where the modeled water surface elevation exceeded the rim/ground surface elevation at a the basins and manholes (i.e. Flooding);
2. Locations where the modeled water surface exceeded the crown of the pipes within the manholes (i.e. Surcharging); or
3. Locations where the anticipated flow in a conveyance structure was greater than its design capacity (i.e. flow is > capacity).

While items noted as surcharging or below capacity identify a system deficiency, this does not necessarily warrant upgrades or improvements. These system deficiencies show that the system is still operating, but as a pressure flow system, instead of a gravity flow system. If no flooding is observed, the flow is still contained within the conveyance system, and the modeling software calculates theoretically accurate downstream and upstream system results based on the operating condition of these components.

Analysis of Design Flood Event – Existing Conditions

The modeled results show a couple of deficiencies in the downstream conveyance structures of the existing CCR impoundment system at STCPP; however, the large capacity of the spillway overflow weir in the west basin prevents the CCR basins themselves from experiencing any modeled deficiencies. During the design flood event, the depth of the water within the basins only rises 0.24 feet above the crest elevation of the weir (elevation 579.0 feet), which still provides approximately 3.26 feet of freeboard in the east basin and 4.64 feet of freeboard in the west basin to the top elevation of the basins, more than the industry standard freeboard. The weirs can manage the peak flow produced by the design flood and peak process flow of 30.8 cfs from the process water and stormwater runoff contributing to



each basin, with a maximum calculated capacity of 3,016 cfs (see Weir Capacity Calculation for details).

The deficiency issues with the system are on the downstream conveyance piping and a result of the reduced downstream system capacity due to the water level at the outfall in the overflow canal, which has a direct hydraulic connection to the St. Clair River. We modeled the system at the river's high water level (determined by observed water staining on the concrete seawall during the topographic survey), of 578.7 feet, 6.2 feet above the invert elevation of the 48-inch RCP outfall into the overflow canal. Because of this, the piping between the overflow weir of the basin and the outfall is in a submerged condition.

Additionally, the model predicts that the 48-inch outlet pipe from the weir outfall structure to the overflow canal is below capacity of the peak inflow and it causes water to back-up into the weir outfall structure. Even though flow backs up into the weir outfall structure, the structure capacity still allows for an operational freeboard of 4.71 feet below the top of weir, and does not affect the hydraulic performance of the basins or the weir. The maximum capacity of the pipe between the weir outfall structure and the catch basin is 24.9 cfs (about 34% of the peak flow).

The model also predicts that the downstream catch basin will flood approximately 0.01 ac-in (approximately 300 gallons) at a rate of 36.8 cfs. The water does not flood and return to the catch basin when system capacity develops, but based on site topographical information, flows to a catch basin at a lower elevation nearby that is not included in the CCR surface impoundment conveyance system. These catch basins are directed to the main lift station which pumps the water to on-site basins where sediment settles out before being pumped to the overflow canal.

Historically, the basins have performed well and, according to DTE personnel, have never flooded in adverse conditions. There is an adequate amount of freeboard in the basins to account for a reasonable level of unforeseen incidents in the event additional flow into or



restricted flow downstream of the basins occurs. DTE staff also inspects the bottom ash CCR impoundment system weekly and after significant rain or storm events to remediate any observed issues as soon as practical.

The model output result file provides additional information regarding the output and results. Refer to Figure 3 for additional information on the existing bottom ash CCR surface impoundment components.

CONCLUSIONS

NTH has prepared this inflow design flood control system plan to demonstrate and document the hydrologic and hydraulic capacity and performance requirements for the bottom ash CCR surface impoundments of the STCPP in accordance with 40 CFR 257.82.

The existing bottom ash CCR impoundment system at STCPP currently conveys both bottom ash and other plant process water and on-site stormwater. The overall hydraulic system comprises the two bottom ash basins, overflow weir, and downstream conveyance structures and piping. While our analysis indicates that the existing downstream conveyance system, which outflows water from the bottom ash basins, experiences deficiencies when modeled at the specified 25-year design event, these deficiencies are independent of the hydraulic performance of the bottom ash basin and overflow structures themselves. Additionally, since the discharge from the basins meets the regulatory National Pollution Discharge Elimination System (NPDES) permit requirements stipulated in the facility's individual permit for both total suspended solids (TSS) and fats, oils, and grease (FOG), the impoundment discharge water that is flooding the downstream conveyance structures would not be considered a release of CCR or regulated wastewater. The modeled outflow from the basins floods out of the downstream catch basin and into a different storm system that is directed to the main lift station and pumped to on-site settling basins before outfalling in the overflow canal, at the NPDES-permitted outfall.



STATEMENT OF CERTIFICATION

I, David R. Lutz, a Professional Engineer licensed in the State of Michigan, certify¹ that NTH Consultants, Ltd. have reviewed available historical information, conducted a field visit, performed engineering and hydraulic/hydrologic analysis, modeling, and calculations on the inflow design flood control system for the bottom ash CCR surface impoundments at the DTE St. Clair Power Plant, located in St. Clair, Michigan. To the best of my knowledge and belief, the analysis and documentation presented in this report for the bottom ash basins at the aforementioned facility is accurate and has been developed in substantial conformance with the requirements stipulated in 40 CFR Part 257.82.



David R. Lutz, P.E.
State of Michigan Professional Engineer
Registration No. 57487

([1]) I am rendering my professional opinion based on the information available to me at the time of this report writing. This certification does not comprise a guarantee or warranty that certain conditions exist, nor does it relieve any other party of their requirements to abide by all applicable local, state, and federal regulations, and to honor all express or customary guarantees and warranties associated with their work.

ATTACHMENTS

- Figure 1: Overall Site Plan
- Figure 2: Topographic Survey
- Figure 3: Existing System Component Plan
- Weir Capacity Calculation
- Time of Concentration Calculation
- Autodesk Storm and Sanitary Analysis Model Output

REFERENCE DOCUMENTS

- 6C516W-132 “BOTTOM ASH SETTLING BASINS AND RELATED FACILITIES GENERAL SITE PLAN”
- 6C516W-133 “BOTTOM ASH SETTLING BASINS RELOCATE BOTTOM ASH BASIN OUTFALL PLAN, PROFILE AND DETAILS”
- 6C516W-134 “BOTTOM ASH SETTLING BASINS CONCRETE APRON AND CHEMICAL TREATMENT TRENCH, SECTIONS AND DETAILS”
- 6C516W-135 “BOTTOM ASH SETTLING BASINS CANAL BETWEEN EAST & WEST CELLS PLANS AND DETAILS”
- 6C516-8 “PLAN & DETAILS OF OVERFLOW CANAL FROM SHOPS BUILDING TO RIVER”
- 6P515-151 “IMPROVEMENT TO LAND – 48” SEWER AND 15” EMERGENCY TRANS. DRAIN & ROAD PLANS”
- 6MS516-99 “GENERAL YARD MAP”
- 6MS516-100 “GENERAL YARD MAP”
- 6MS516-103 “GENERAL YARD MAP”
- BOTTOM ASH FLOW 2013-PRESENT DATA



ATTACHMENTS

- **FIGURE 1: OVERALL SITE PLAN**
- **FIGURE 2: TOPOGRAPHIC SURVEY**
- **FIGURE 3: EXISTING SYSTEM COMPONENT PLAN**
- **WEIR CAPACITY CALCULATION**
- **TIME OF CONCENTRATION CALCULATION**
- **AUTODESK STORM AND SANITARY ANALYSIS MODEL OUTPUT**




NTH PROJECT No.: 62-160047	CAD FILE NAME: 160047-SCPP
DESIGNED BY: SLG	PLOT DATE: 9/27/2016
DRAWN BY: SLG	DRAWING SCALE: 1" = 300'
CHECKED BY: DRL	INCEPTION DATE: 9/7/2016




NTH Consultants, Ltd.
Infrastructure Engineering
and Environmental Services

SITE LOCATION PLAN
ST. CLAIR POWER PLANT EAST CHINA TOWNSHIP, MI

FIGURE: 1



ST. CLAIR POWER PLANT ASH SETTLING BASINS



UTILITY WARNING

UNDERGROUND UTILITY LOCATIONS, AS SHOWN ON THE PLAN, WERE OBTAINED FROM UTILITY OWNERS, AND FIELD LOCATION WHERE POSSIBLE. MCNEELY & LINCOLN CAN NOT GUARANTEE THE ACCURACY AND COMPLETENESS OF THE UTILITY INFORMATION.


A MINIMUM OF 3 WORKING DAYS PRIOR TO BEGINNING CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY "MISS DIG" AND HAVE ALL UNDERGROUND UTILITIES STAKED BEFORE ANY WORK MAY BEGIN.

THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL UTILITIES THAT MAY INTERFERE WITH CONSTRUCTION.



NTH Figure 2

DATUM INFORMATION:
 HORIZONTAL DATUM = DTE PLANT DATUM
 ORIGIN UNKNOWN
 VERTICAL DATUM = DTE PLANT DATUM
 ORIGIN UNKNOWN





DATE: 07/05/16	SUR BY: TFS/GW	DRWN BY: DFV	CHKD BY: MRD	FIELD BK: 840
CLIENT: McNEELY & LINCOLN ASSOCIATES, INC. NTH CONSULTANTS, LTD. 41780 SIX MILE RD NORTHVILLE, MI 48168				
PROJECT: TOPOGRAPHIC SURVEY - ASH BASIN ST. CLAIR POWER PLANT				
SHEET: 1 OF 1				
FILE NAME: 8243.03 TOP2.DWG				
SHEET: 1 OF 1				
REV. A				
REVISIONS				
LE D C B A				
UPDATED SURFACE TO INCLUDE COLL. TRENCH				



NTH Consultants, Ltd.

Infrastructure Engineering and Environmental Services

Northville, MI 248.553.6300
Detroit, MI 313.237.3900
Lansing, MI 517.484.6900
Grand Rapids, MI 616.451.6270
Cleveland, OH 216.334.4040



LEGEND

- 580 — EXISTING CONTOUR LINE
- EXISTING GRAVEL DRIVE
- //// EXISTING BUILDING
- EXISTING GUARDRAIL
- == EXISTING PIPING
- EXISTING MANHOLE
- DRAINAGE BOUNDARY

SUBMITTAL			
REV	DESCRIPTION	DATE	BY

PROJECT NAME:
DTE ST. CLAIR POWER PLANT - BOTTOM ASH BASIN HYDRAULIC ANALYSIS

PROJECT LOCATION:
ST. CLAIR POWER PLANT
EAST CHINA TOWNSHIP,
MICHIGAN

NTH PROJECT NO.: 62-160047	CAD FILE NAME: 160047-SC-SP
DESIGNED BY: SLG	INCEP DATE: 9/7/2016
DRAWN BY: SLG	DRAWING SCALE: 1" = 30'
CHECKED BY: DRL	SUBMITTED DATE: 9/27/2016

SHEET TITLE:
ST. CLAIR POWER PLANT
BOTTOM ASH BASIN

EXISTING SYSTEM
COMPONENT PLAN

SHEET REFERENCE NUMBER:

J:\2016\21_160047\production_nah\scsp\160047-sc-sp.dwg Plot Date: 9/27/2016 9:48 AM by agent



NTH Consultants, Ltd.

Infrastructure Engineering
and Environmental Services

Job DTE Hydro Analysis	Project No. 62-160047	Sheet No. 1
Subject STCP Weir	By SLG	Date 9/21/2016
Capacity Calculation	Checked By KBD	Date 9/23/2016

Calculate capacity of weir for STCP bottom ash basins

Use broad-crested weir equation

$$Q = C_s b H^{3/2}$$

$$C_s = 3.33 \text{ ft}^{0.5}/\text{sec}$$

$$b = 84 \text{ ft}$$

$$H = 4.88 \text{ ft}$$

$$Q = 3.33 \text{ ft}^{0.5}/\text{sec} \cdot 84 \text{ ft} \cdot (4.88 \text{ ft})^{3/2} = \boxed{3016 \text{ cfs}}$$

Height of water at maximum flow rate

$$Q_{\text{max}} = 27.1 \text{ cfs}$$

$$Q = C_s b H^{3/2} \rightarrow H = \left(\frac{Q}{C_s b} \right)^{2/3} = \left(\frac{27.1 \text{ cfs}}{3.33 \text{ ft}^{0.5}/\text{sec} \cdot 84 \text{ ft}} \right)^{2/3}$$

$$\boxed{H = 0.2 \text{ ft}}$$

DTE St. Clair Power Plant Drainage Areas 62-160047						
Area #	Overland Flow		Pipe Flow	Tc (hrs.)	Tc (min.)	
CB-1	L (ft)	72.00		0.132	7.9	
	S (%)	0.10				
	V (ft/s)	0.15				
	T (hrs)	0.132				
	L (ft)	118.00		0.068	4.1	
	S (%)	1.00				
	V (ft/s)	0.48				
	T (hrs)	0.068	Tc		12.0	
East Basin	L (ft)	67.00		0.046	2.8	
	S (%)	0.70				
	V (ft/s)	0.40				
	T (hrs)	0.046	Tc		2.8	
West Basin	L (ft)	87.00		0.038	2.3	
	S (%)	1.80				
	V (ft/s)	0.64				
	T (hrs)	0.038				
	L (ft)	60.00		0.035	2.1	
	S (%)	1.00				
	V (ft/s)	0.48				
	T (hrs)	0.035	Tc		4.3	
Coal Handling (drains to CB-1)	L (ft)	86.00		0.070	4.2	
	S (%)	0.50				
	V (ft/s)	0.34				
	T (hrs)	0.070				
	L (ft)	102.00	L (ft)	102.00	0.012	0.7
	S (%)	0.20	S (%)	0.20		
	D (ft)	1.25	D (ft)	1.25		
	R (ft)	0.31	R (ft)	0.31		
	C	94.42	C	94.42		
	V (ft/s)	2.36	V (ft/s)	2.36		
	T (hrs)	0.012	T (hrs)	0.012		
	L (ft)	391.00	L (ft)	391.00	0.042	2.5
	S (%)	0.15	S (%)	0.15		
	D (ft)	1.75	D (ft)	1.75		
	R (ft)	0.44	R (ft)	0.44		
	C	99.86	C	99.86		
	V (ft/s)	2.56	V (ft/s)	2.56		
	T (hrs)	0.042	T (hrs)	0.042		
	L (ft)	351.00	L (ft)	351.00	0.038	2.3
	S (%)	0.05	S (%)	0.05		
	D (ft)	4.00	D (ft)	4.00		
	R (ft)	1.00	R (ft)	1.00		
	C	114.62	C	114.62		
	V (ft/s)	2.56	V (ft/s)	2.56		
	T (hrs)	0.038	T (hrs)	0.038		
Tc	9.8					
Office Building (drains to CB-1)	L (ft)	181.00		0.148	8.9	
	S (%)	0.50				
	V (ft/s)	0.34				
	T (hrs)	0.148				
	L (ft)	351.00	L (ft)	351.00	0.038	2.3
	S (%)	0.05	S (%)	0.05		
	D (ft)	4.00	D (ft)	4.00		
	R (ft)	1.00	R (ft)	1.00		
	C	114.62	C	114.62		
	V (ft/s)	2.56	V (ft/s)	2.56		
	T (hrs)	0.038	T (hrs)	0.038		
Tc	11.2					

Overland Flow
L = distance in feet
S = slope in %
T = time of travel in hours = $L / (V * 3600)$
 $V = 0.48 * \sqrt{S}$ - Sheet Flow < 300'

Pipe Flow
L = distance in feet
S = slope in %
D = diameter
R = wetted perimeter
C = Roughness Coefficient = $(1.49/n) * R^{(1/6)}$
Pipe Velocity = $C * \sqrt{R * S}$
T = time of travel in hours = $L / (V * 3600)$

Dia	Slope
8	0.54
12	0.32
21	0.15
24	0.13
48	0.05
15	0.2

DTE St. Clair Power Plant

Existing System Model Output

Autodesk® Storm and Sanitary Analysis 2016 - Version 11.1.1.55 (Build 1)

Project Description

File Name St. Clair.SPF

Analysis Options

Flow Units cfs
Subbasin Hydrograph Method. Rational
Time of Concentration..... SCS IR-55
Return Period..... 25 years
Link Routing Method Hydrodynamic
Storage Node Exfiltration.. None
Starting Date JUL-19-2016 00:00:00
Ending Date JUL-19-2016 02:00:00
Report Time Step 00:00:10

Element Count

Number of subbasins 3
Number of nodes 5
Number of links 4

Subbasin Summary

Subbasin Total
 Area
 Fl²

Sub-01 55201.49
Sub-02 43837.17
Sub-03 21363.92

Node Summary

DTE St. Clair Power Plant

Existing System Model Output

```

*****
Node ID Element Type Invert Elevation ft Maximum Elev. ft Poned Area ft? External Inflow
-----
CB-1 JUNCTION 573.00 583.78 0.00 Yes
Outfall 572.50 576.50 0.00
East-Basin STORAGE 571.70 582.51 0.00 Yes
Weir-Box STORAGE 570.69 583.88 0.00
West-Basin STORAGE 573.01 583.88 0.00

*****
Link Summary
*****
Link ID From Node To Node Element Type Length ft Slope % Manning's Roughness
-----
48-in-1 Weir-Box CB-1 CONDUIT 191.3 0.0314 0.0130
48-in-2 CB-1 Outfall CONDUIT 66.0 0.7576 0.0130
Box-Culvert East-Basin West-Basin CHANNEL 66.0 0.3030 0.0130
Weir Weir-Box WEIR

*****
Cross Section Summary
*****
Link ID Shape Depth/Diameter ft Width ft No. of Barrels Sectional Area ft? Full Flow Hydraulic Radius ft Design Flow Capacity cfs
-----
48-in-1 CIRCULAR 4.00 4.00 1 12.57 1.00 25.44
48-in-2 CIRCULAR 4.00 4.00 1 12.57 1.00 125.03
Box-Culvert RECT_OPEN 6.90 8.70 1 60.03 2.67 726.63

*****
Runoff Quantity Continuity
*****
Total Precipitation ..... 0.255
Continuity Error (%) ..... 0.107

*****
Flow Routing Continuity
*****
Volume acre-ft Volume Mgalloons
-----

```

DTE St. Clair Power Plant

Existing System Model Output

```

*****
External Inflow ..... 5.404
External Outflow ..... 1.761
Initial Stored Volume ... 4.993
Final Stored Volume ... 13.122
Continuity Error (%) ... 13.743
                    ... 4.276
                    ... 4.478
                    ... 0.001
    
```

 Runoff Coefficient Computations Report

```

-----
Subbasin Sub-01
-----
Soil/Surface Description      Area      Soil      Runoff
                               (ft²)    Group    Coeff.
-----
Composite Area & Weighted Runoff Coeff.
                               55201.49  -        0.90
                               55201.49
    
```

 Subbasin Sub-02

```

Soil/Surface Description      Area      Soil      Runoff
                               (ft²)    Group    Coeff.
-----
Composite Area & Weighted Runoff Coeff.
                               43837.17  -        0.90
                               43837.17
    
```

 Subbasin Sub-03

```

Soil/Surface Description      Area      Soil      Runoff
                               (ft²)    Group    Coeff.
-----
Composite Area & Weighted Runoff Coeff.
                               21363.92  -        0.90
                               21363.92
    
```

 SCS TR-55 Time of Concentration Computations Report

Sheet Flow Equation

DTE St. Clair Power Plant

Existing System Model Output

$$Tc = (0.007 * ((n * Lf)^{0.8})) / ((P^{0.5}) * (Sf^{0.4}))$$

Where:

Tc = Time of Concentration (hrs)

n = Manning's Roughness

Lf = Flow Length (ft)

P = 2 Yr, 24 hr Rainfall (inches)

Sf = Slope (ft/ft)

Shallow Concentrated Flow Equation

V = 16.1345 * (Sf^{0.5}) (unpaved surface)

V = 20.3282 * (Sf^{0.5}) (paved surface)

V = 15.0 * (Sf^{0.5}) (grassed waterway surface)

V = 10.0 * (Sf^{0.5}) (nearly bare & untilled surface)

V = 9.0 * (Sf^{0.5}) (cultivated straight rows surface)

V = 7.0 * (Sf^{0.5}) (short grass pasture surface)

V = 5.0 * (Sf^{0.5}) (woodland surface)

V = 2.5 * (Sf^{0.5}) (forest w/heavy litter surface)

Tc = (Lf / V) / (3600 sec/hr)

Where:

Tc = Time of Concentration (hrs)

Lf = Flow Length (ft)

V = Velocity (ft/sec)

Sf = Slope (ft/ft)

Channel Flow Equation

V = (1.49 * (R^{2/3}) * (Sf^{0.5})) / n

R = Aq / Wp

Tc = (Lf / V) / (3600 sec/hr)

Where:

Tc = Time of Concentration (hrs)

Lf = Flow Length (ft)

R = Hydraulic Radius (ft)

Aq = Flow Area (ft²)

Wp = Wetted Perimeter (ft)

V = Velocity (ft/sec)

DTE St. Clair Power Plant

Existing System Model Output

Sf = Slope (ft/ft)
 n = Manning's Roughness

 Subbasin Sub-01

User-Defined TOC override (minutes): 2.80

 Subbasin Sub-02

User-Defined TOC override (minutes): 4.30

 Subbasin Sub-03

User-Defined TOC override (minutes): 12.00

 Subbasin Runoff Summary

Subbasin ID	Accumulated Precip in	Rainfall Intensity in/hr	Total Runoff in	Peak Runoff cfs	Weighted Runoff Coeff	Time of Concentration days	Retention Time hh:mm:ss
Sub-01	1.11	4.43	1.00	5.05	0.900	0	00:15:00
Sub-02	1.11	4.43	1.00	4.01	0.900	0	00:15:00
Sub-03	1.11	4.43	1.00	1.96	0.900	0	00:15:00

 Node Depth Summary

Node ID	Average Depth Attained ft	Maximum Depth Attained ft	HGL Attained ft	Time of Max Occurrence days	Peak Runoff Volume acre-in	Total Time Flooded minutes	Retention Time hh:mm:ss

DTE St. Clair Power Plant

Existing System Model Output

CB-1	5.81	10.78	583.78	0	00:00	0.01	0	0:00:00
Outfall	6.20	578.70	0	00:00	0	0	0:00:00	
East-Basin	7.52	579.25	0	00:24	0	0	0:00:00	
Weir-Box	8.22	579.17	0	00:02	0	0	0:00:00	
West-Basin	6.19	579.24	0	00:24	0	0	0:00:00	

Node Flow Summary

Node ID	Element Type	Maximum Lateral Inflow cfs	Peak Inflow cfs	Time of Peak Inflow Occurrence days hh:mm	Maximum Flooding Overflow cfs	Time of Peak Flooding Occurrence days hh:mm
CB-1	JUNCTION	6.05	134.51	0 00:00	48.47	0 00:00
Outfall	OUTFALL	0.00	130.38	0 00:00	0.00	
East-Basin	STORAGE	32.19	32.19	0 00:15	0.00	
Weir-Box	STORAGE	0.00	73.19	0 00:01	0.00	
West-Basin	STORAGE	4.01	38.46	0 00:02	0.00	

Storage Node Summary

Storage Node ID	Maximum Pondered Volume 1000 ft ³	Maximum Pondered Volume (%)	Time of Max Pondered Volume days hh:mm	Average Pondered Volume 1000 ft ³	Average Pondered Volume (%)	Maximum Storage Node Outflow cfs	Maximum Exfiltration Rate cfm	Time of Max. Exfiltration Rate hh:mm:ss	Total Exfiltrated Volume 1000 ft ³
East-Basin	317.893	75	0 00:24	316.638	75	29.22	0.00	0:00:00	0.000
Weir-Box	11.399	63	0 00:02	11.031	61	30.87	0.00	0:00:00	0.000
West-Basin	266.462	63	0 00:24	265.160	62	30.83	0.00	0:00:00	0.000

Outfall Loading Summary

Outfall Node ID	Flow Frequency	Average Flow	Peak Inflow

DTE St. Clair Power Plant

Existing System Model Output

	(%)	cfs	cfs
Outfall	100.00	31.67	130.38
System	100.00	31.67	130.38

 Link Flow Summary

Link ID	Element Type	Time of Peak Flow Occurrence days hh:mm	Maximum Velocity Attained ft/sec	Length Factor	Peak Flow during Analysis cfs	Design Flow Capacity cfs	Ratio of Maximum Flow /Design Flow	Ratio of Maximum Flow Depth	Total Time Surcharged minutes	Reported Condition
48-in-1	CONDUIT	0 00:01	6.47	1.00	72.50	25.44	2.85	1.00	118	SURCHARGED
48-in-2	CONDUIT	0 00:00	11.19	1.00	130.38	125.03	1.04	1.00	120	SURCHARGED
Box-Culvert	CHANNEL	0 00:22	0.98	1.00	29.22	726.63	0.04	0.50	0	Calculated
Weir	WEIR	0 00:24			30.83			0.05		

 Highest Flow Instability Indexes

 All links are stable.

Analysis began on: Tue Sep 27 09:03:24 2016
 Analysis ended on: Tue Sep 27 09:03:24 2016
 Total elapsed time: < 1 sec